



Construction Specialties Inc. certifies that the louver model A6155 shown herein is licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified ratings Program. The AMCA Certified Ratings Seal applies to air performance ratings and water penetration

AIRFLOW DATA

For a 4 Foot by 4 Foot Unit

- Free area = 7.80 ft² (0.742 m²)
- Percent free area = 48.75%
- Free area velocity at the point of beginning water penetration (@0.01oz. / ft² of free area based on a 15 minute interval test) = 1047 FPM (5.32 m/s)
- Maximum recommended air intake velocity = 847 FPM (4.30 m/s)
Air volume @ 847 FPM free area velocity = 6606 CFM (3.12 m³/s)
Pressure drop @ 847 FPM free area velocity = 0.10 in. H₂O (23.6 Pa)
- Maximum recommended air exhaust velocity = 2003 FPM (10.18 m/s)
Air volume @ 2003 FPM free area velocity = 15623 CFM (7.37 m³/s)
Pressure drop @ 2003 FPM free area velocity = 0.50 in. H₂O (124.2 Pa)



SUGGESTED SPECIFICATIONS:

GENERAL: Furnish and install where indicated on the drawings C/S 6" (152.4 mm) DOUBLE DRAIN FIXED EXTRUDED RECESSED MULLION LOUVER **MODEL A6155** as manufactured by Construction Specialties, Inc. Lebanon, New Jersey. Complete details shall be submitted to the architect for approval prior to fabrication. The supplier must be a member of AMCA or BSRIA.



MATERIAL: Heads, sills, jambs, and mullions to be one piece structural members of 6063-T52 alloy with integral caulking slot and retaining beads. Mullions shall be sliding interlock with integral internal drain(s). Blades to be one piece extrusions with gutter(s) designed to catch and direct water to jamb and mullion drains. Extrusion thicknesses shall be as follows: Heads, Sills, jambs, and mullions: 0.081" (2.06 mm). Fixed Blades: 0.081" (2.06 mm). Closed cell compression gaskets shall be provided between bottom of the mullion or jamb and the top of the sill to insure leak tight connections. All fasteners to be aluminum or stainless steel. All louvers to be furnished with 5/8" (15.87 mm) flattened expanded mesh, aluminum bird screen with a 0.055" (1.4 mm) thick extruded aluminum frame. Screens and screen frames to be standard mill finish.

STRUCTURAL DESIGN: Structural supports shall be designed and furnished by the louver manufacturer to carry a wind load of not less than _____ psf (Pascals). (Note: If this paragraph is omitted or if the design wind load is not specified, the louvers will be manufactured in self-supporting units up to a maximum of 5' (1524 mm) wide by 8' (2438 mm) high. Any additional structural supports required to adequately secure these units within the opening shall be the responsibility of others.)

TEST DATA: The louver manufacturer shall submit test data on a 4' x 4' (1.22 m x 1.22 m) unit showing that the louver conforms to the following: (Based on a 15 min test duration)

| | |
|--|--|
| Free area: | 7.80 ft ² (0.742 m ²) |
| Free area velocity at point of beginning water penetration (0.01 oz/ft ²): | 1047 FPM (5.32 m/s) |
| Intake pressure drop at 0.01 oz.ft ² free area velocity: | 0.14 in. H ₂ O (34.8 Pa) |
| Exhaust pressure drop at 1000 FPM (5.08 m/s) free area velocity: | 0.13 in. H ₂ O (32.3 Pa) |

FINISH: All louvers shall be finished with C/S Powder Coat, a coating to be 1.5 to 3 mil. thick full strength **100% resin Fluoropolymer coating. Finish to allow zero VOCs** to be emitted into facility of application. Finish to adhere to a 4H Hardness rating. All finishing procedures shall be one continuous operation in the plant of the manufacturer. **The coating shall meet or exceed all requirements of AAMA specification 2605** "Voluntary Specification for High Performance Organic Coatings on Architectural extrusions and Panels." The louver manufacturer shall supply an industry standard **20-year limited warranty against failure or excessive fading** of the Fluoropolymer Powder Coat finish. This limited warranty shall begin on the date of material shipment.



PLAN VIEW
SCALE: 1-1/2" = 1'
Discharge Coefficient
Intake Cd = 0.38 (Class 2)
AMCA certifies the coefficient class only

PERFORMANCE DATA MODEL A6155

Width in Inches and Meters

| | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 |
|------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| | 0.46 | 0.61 | 0.76 | 0.91 | 1.07 | 1.22 | 1.37 | 1.52 |
| 18 | 0.36 | 0.51 | 0.66 | 0.81 | 0.96 | 1.11 | 1.26 | 1.42 |
| 0.46 | 0.03 | 0.05 | 0.06 | 0.08 | 0.09 | 0.10 | 0.12 | 0.13 |
| 24 | 0.72 | 1.02 | 1.32 | 1.62 | 1.93 | 2.23 | 2.53 | 2.83 |
| 0.61 | 0.07 | 0.09 | 0.12 | 0.15 | 0.18 | 0.21 | 0.24 | 0.26 |
| 30 | 1.43 | 2.04 | 2.64 | 3.25 | 3.85 | 4.46 | 5.06 | 5.66 |
| 0.76 | 0.13 | 0.19 | 0.25 | 0.30 | 0.36 | 0.41 | 0.47 | 0.53 |
| 36 | 1.79 | 2.55 | 3.30 | 4.06 | 4.81 | 5.57 | 6.32 | 7.08 |
| 0.91 | 0.17 | 0.24 | 0.31 | 0.38 | 0.45 | 0.52 | 0.59 | 0.66 |
| 42 | 2.15 | 3.06 | 3.96 | 4.87 | 5.78 | 6.68 | 7.59 | 8.50 |
| 1.07 | 0.20 | 0.28 | 0.37 | 0.45 | 0.54 | 0.62 | 0.71 | 0.79 |
| 48 | 2.51 | 3.57 | 4.63 | 5.68 | 6.74 | 7.80 | 8.85 | 9.91 |
| 1.22 | 0.23 | 0.33 | 0.43 | 0.53 | 0.63 | 0.72 | 0.82 | 0.92 |
| 54 | 2.87 | 4.08 | 5.29 | 6.49 | 7.70 | 8.91 | 10.12 | 11.33 |
| 1.37 | 0.27 | 0.38 | 0.49 | 0.60 | 0.72 | 0.83 | 0.94 | 1.05 |
| 60 | 3.23 | 4.59 | 5.95 | 7.31 | 8.67 | 10.03 | 11.38 | 12.74 |
| 1.52 | 0.30 | 0.43 | 0.55 | 0.68 | 0.81 | 0.93 | 1.06 | 1.18 |
| 66 | 3.59 | 5.10 | 6.61 | 8.12 | 9.63 | 11.14 | 12.65 | 14.16 |
| 1.68 | 0.33 | 0.47 | 0.61 | 0.75 | 0.89 | 1.03 | 1.18 | 1.32 |
| 72 | 3.95 | 5.61 | 7.27 | 8.93 | 10.59 | 12.25 | 13.91 | 15.58 |
| 1.83 | 0.37 | 0.52 | 0.68 | 0.83 | 0.98 | 1.14 | 1.29 | 1.45 |
| 78 | 4.30 | 6.12 | 7.93 | 9.74 | 11.55 | 13.37 | 15.18 | 16.99 |
| 1.98 | 0.40 | 0.57 | 0.74 | 0.91 | 1.07 | 1.24 | 1.41 | 1.58 |
| 84 | 4.66 | 6.63 | 8.59 | 10.55 | 12.52 | 14.48 | 16.44 | 18.41 |
| 2.13 | 0.43 | 0.62 | 0.80 | 0.98 | 1.16 | 1.35 | 1.53 | 1.71 |
| 90 | 5.02 | 7.14 | 9.25 | 11.37 | 13.48 | 15.59 | 17.71 | 19.82 |
| 2.29 | 0.47 | 0.66 | 0.86 | 1.06 | 1.25 | 1.45 | 1.65 | 1.84 |
| 96 | 5.38 | 7.65 | 9.91 | 12.18 | 14.44 | 16.71 | 18.97 | 21.24 |
| 2.44 | 0.50 | 0.71 | 0.92 | 1.13 | 1.34 | 1.55 | 1.76 | 1.97 |
| 102 | 5.74 | 8.16 | 10.57 | 12.99 | 15.41 | 17.82 | 20.24 | 22.66 |
| 2.59 | 0.53 | 0.76 | 0.98 | 1.21 | 1.43 | 1.66 | 1.88 | 2.10 |
| 108 | 6.10 | 8.67 | 11.23 | 13.80 | 16.37 | 18.94 | 21.50 | 24.07 |
| 2.74 | 0.57 | 0.81 | 1.04 | 1.28 | 1.52 | 1.76 | 2.00 | 2.24 |
| 114 | 6.46 | 9.18 | 11.89 | 14.61 | 17.33 | 20.05 | 22.77 | 25.49 |
| 2.90 | 0.60 | 0.85 | 1.11 | 1.36 | 1.61 | 1.86 | 2.12 | 2.37 |
| 120 | 7.17 | 10.20 | 13.22 | 16.24 | 19.26 | 22.28 | 25.30 | 28.32 |
| 3.05 | 0.67 | 0.95 | 1.23 | 1.51 | 1.79 | 2.07 | 2.35 | 2.63 |
| 126 | 7.53 | 10.71 | 13.88 | 17.05 | 20.22 | 23.39 | 26.56 | 29.74 |
| 3.20 | 0.70 | 0.99 | 1.29 | 1.58 | 1.88 | 2.17 | 2.47 | 2.76 |
| 132 | 7.89 | 11.21 | 14.54 | 17.86 | 21.18 | 24.51 | 27.83 | 31.15 |
| 3.35 | 0.73 | 1.04 | 1.35 | 1.66 | 1.97 | 2.28 | 2.59 | 2.89 |
| 138 | 8.25 | 11.72 | 15.20 | 18.67 | 22.15 | 25.62 | 29.09 | 32.57 |
| 3.51 | 0.77 | 1.09 | 1.41 | 1.73 | 2.06 | 2.38 | 2.70 | 3.03 |
| 144 | 8.61 | 12.23 | 15.86 | 19.48 | 23.11 | 26.73 | 30.36 | 33.98 |
| 3.66 | 0.80 | 1.14 | 1.47 | 1.81 | 2.15 | 2.48 | 2.82 | 3.16 |
| 150 | 8.97 | 12.74 | 16.52 | 20.30 | 24.07 | 27.85 | 31.62 | 35.40 |
| 3.81 | 0.83 | 1.18 | 1.53 | 1.89 | 2.24 | 2.59 | 2.94 | 3.29 |
| 156 | 9.33 | 13.25 | 17.18 | 21.11 | 25.03 | 28.96 | 32.89 | 36.82 |
| 3.96 | 0.87 | 1.23 | 1.60 | 1.96 | 2.33 | 2.69 | 3.06 | 3.42 |
| 162 | 9.69 | 13.76 | 17.84 | 21.92 | 26.00 | 30.08 | 34.15 | 38.23 |
| 4.11 | 0.90 | 1.28 | 1.66 | 2.04 | 2.42 | 2.79 | 3.17 | 3.55 |
| 168 | 10.04 | 14.27 | 18.50 | 22.73 | 26.96 | 31.19 | 35.42 | 39.65 |
| 4.27 | 0.93 | 1.33 | 1.72 | 2.11 | 2.50 | 2.90 | 3.29 | 3.68 |
| 174 | 10.40 | 14.78 | 19.16 | 23.54 | 27.92 | 32.30 | 36.68 | 41.06 |
| 4.42 | 0.97 | 1.37 | 1.78 | 2.19 | 2.59 | 3.00 | 3.41 | 3.81 |
| 180 | 10.76 | 15.29 | 19.82 | 24.36 | 28.89 | 33.42 | 37.95 | 42.48 |
| 4.57 | 1.00 | 1.42 | 1.84 | 2.26 | 2.68 | 3.10 | 3.53 | 3.95 |
| 186 | 11.12 | 15.80 | 20.48 | 25.17 | 29.85 | 34.53 | 39.21 | 43.90 |
| 4.72 | 1.03 | 1.47 | 1.90 | 2.34 | 2.77 | 3.21 | 3.64 | 4.08 |
| 192 | 11.48 | 16.31 | 21.15 | 25.98 | 30.81 | 35.65 | 40.48 | 45.31 |
| 4.88 | 1.07 | 1.52 | 1.96 | 2.41 | 2.86 | 3.31 | 3.76 | 4.21 |
| 198 | 11.84 | 16.82 | 21.81 | 26.79 | 31.78 | 36.76 | 41.74 | 46.73 |
| 5.03 | 1.10 | 1.56 | 2.03 | 2.49 | 2.95 | 3.42 | 3.88 | 4.34 |
| 204 | 12.20 | 17.33 | 22.47 | 27.60 | 32.74 | 37.87 | 43.01 | 48.14 |
| 5.18 | 1.13 | 1.61 | 2.09 | 2.56 | 3.04 | 3.52 | 4.00 | 4.47 |

Height in Inches and Meters

0.50
12.70

0.30
7.62

0.20
5.08


0.10
2.54

0.05
1.27

0.03
0.76

Water Penetration Statement

AMCA defines the point of beginning water penetration as the free area velocity at which the AMCA water test has yielded 0.01 or less ounces of water per square foot of louver free area during a 15-minute test period.



AIR VELOCITY IN FEET AND METERS PER MINUTE THROUGH FREE AREA

**For a 48" X 48" sized louver test to figure 5.5.
Data corrected to standard air density.**

**Construction Specialties, Inc.
Manufacturing & Sales Locations**

www.c-sgroup.com

Lebanon, New Jersey
3 Werner Way 08833
Telephone: (800) 631-7379
louvers@c-sgroup.com

For assistance with overseas requirements, call
C/S International (908) 236-0800

©Copyright July 2020. Construction Specialties, Inc., reserves the right to make design changes or to withdraw any design without notice.

A6155-8

Upper Numerals English Units/Lower Numerals Metric Units