

Yilida Air Conditioning Ventilation

WPH Roof Fan WPH 屋顶风机

Zhejiang Yilida Ventilator Co., Ltd. 浙江亿利达风机股份有限公司 Yilida Road, Hengjie, Luqiao District, Taizhou City, Zhejiang, China P.C: 318056 中国浙江台州市路桥区横街亿利达路

Hot Line (全球服务热线) : 400 1135 666 International Trade (国际贸易) : +86 576 82622666 www.yilida.com

Version Number: A201606 The rights of final interpretation of this brochure belongs to Yilida. © 2016 All Rrights Reserved by Yilida

版本号:A20160 该手册最终解释权归亿利达股份公司所有 ©2016亿利达拥有版权并保留所有权利

Reference: WPH-CY-2017, March 2017

本样本中所述的风机特性,如尺寸、性能参数等,本公司保留更改的权利,怨不另行通知;如新不明之处,请来电询问。 This fan features described in the sample, such as size, performance parameters, the Company reserves the right to change without notice; funknown place, please call us.





目录 CONTENTS



风机应用部分	Fan Applicat	tions	风机产品部分	Fan Products
AMCA Introduction AMCA 介绍	002	2-005	WPH	026-043
Fan Basics and Applica 风机基础及应用	tions 006	5-011		
Fan Vibration and Bala 风机的振动和平衡	ncing 012	2-018		
The Basics of Sound 风机的声音基础	019	9-022		
The Effects of Tempera and Altitude 温度与海拔对选型的影响	ture 023	3-025		



A). 什么是AMCA 国际?

A). What is AMCA International?

空气运动及控制协会(AMCA 国际),是一家非盈利性的国际性组织,它的成员大多是世界各国与空气系统有关的生产商,涉及产品主要包括(但也不仅限于):工商业和家用的风机、百叶窗、风阀、空气幕、空气流量测量装置、噪声衰减器及其它空气系统组件。

AMCA 的使命是促进空气运动及控制行业与公众利益一致 并健康发展。AMCA 国际是一种非常有价值的资源,同时也 是行业自律的强有力组织。人们不论是购买还是指定风机、 风阀和百叶窗,都一定要充分了解 AMCA 国际认证额定值 印章的价值。

在过去的 90 年中,AMCA 国际代表空气运动及控制行业发展的行业领军者,为其会员提供下列有利价值的服务:

- 1) 认证额定值程序
- 2) 独一无二的国家级检测实验室
 3) 参与标准的制定
 4) AMCA 认证的独立实验室(马来西亚/韩国/法国/迪拜)
- 5) 行业统计和预测报告

The Air Movement and Control Association (AMCA International), Inc. is a not-for-profit international association of the world's manufacturers of related air system equipment, primarily, but not limited to: fans, louvers, dampers, air curtains, airflow measurement stations, acoustic attenuators, and other air system components for the industrial, commercial and residential markets.

The association's mission is to promote the health and growth of the air movement and control industry consistent with the interest of the public. AMCA International is a valuable resource and a strong means of self regulation for our industry. People who buy and specify fans, dampers, and louvers need to be aware of the value of the AMCA International Certified Ratings Seal.

During the last 90 years of representing the air movement and control industry , AMCA International has provided value to its membership with the following services:

- 1) Certified Ratings Program
- 2) Unique state-of-the art testing laboratory
- 3) Participation in the development of standards
- Independent AMCA accredited laboratories in Malaysia, Korea, France, Dubai.
- 5) Industry statistics and forecasting reports

B). 认证额定值程序 (CRP)

 AMCA 国际的认证额定值程序(CRP),保证产品系列已 经过测试,及其额定值已达到 AMCA 国际的测试标准和额 定要求。

2)当产品经过测试,并且其样本提交给AMCA国际的工作 人员批准后,AMCA的性能印章会显示在样本和设备上。要 维持额定值的认证,每一个经授权的产品系列都要接受3年 一次的重复检测。发布的性能参数都经过核实为准确并有效 的。

3) AMCA 国际的认证额定值印章向空气运动及控制设备的 采购员、专业人士和终端用户保证,生产商公布的额定值是 可靠和准确的。

4) AMCA 的认证额定值程序向采购员和专业人士保证,各 竞争者的额定值都是基于标准的测试方法和程序得出,并由 AMCA 国际作为一个公平的权威机构来进行审核。

5)所有AMCA认证的产品都列入网站,以便您可以验证出您购买的产品是否在行列中。你在购买之前,请检查AMCA 在线目录的认证产品www.amca.org。

B). Certified Rating Program (CRP)

 AMCA International's Certified Ratings Program (CRP) assures that a product line has been tested and rated in conformance with AMCA International's test standards and rating requirements.

- 2) Performance seals may be displayed in literature and on equipment after a product has been tested and its cataloged ratings have been submitted to and approved by AMCA International's staff. To maintain a ratings certification, each licensed product line is subject to retesting every 3 years. Published performance is checked for accuracy and validity.
- 3) An AMCA Certified Ratings Seal gives the buyer, specifier, and end-user of air movement and control equipment assurance that published ratings are reliable and accurate.
- 4) The AMCA certified ratings program assures buyers and specifiers that competitors' ratings are based on standard test methods and procedures, and are subject to review by AMCA International as an impartial authority.
- 5) All AMCA certified products are listed on line, so you can verify that the product you are buying is listed. Before you buy, check out the AMCA online Directory of Certified Products at www.amca.org.



C).风机的测试及标准

C). Fans Testing and Standards

1) Air Performance Testing includes:

AMCA 国际的实验室可以对风机进行以下的测试:

1) 风机的空气性能测试包括:

风机性能的发展。

・流量、压力、功率和效率的测量。

适用于空气性能测试的测试标准,包括: · AMCA 标准 210-07,实验室测试风机气动性能额定值 认证的方法。

·AMCA标准220-05,空气幕机组的测试方法。

·AMCA 标准 230-07, 实验室测试空气循环风机额定值的方法。

·AMCA 标准 240-06, 实验室测试正压通风机额定值的 方法。

2) 风机的声音测试包括:

- ・进口的声功率。
- ・出口的声功率。
- ・ 总声功率。
- 适用于声音测试的测试标准,包括:
- ·AMCA标准300-08,混响室测试风机声音的方法。

3) 风机的能源效率测试包括:

· 风机效率等级 (FEG) 对风机的效率进行分级。 适用于风机的能源效率测试的测试标准,包括: · AMCA 标准 205-10,风机能源效率分级。



Development of the fan curves.
Measurement of airflow, pressure, power and efficiency.
Test standards that apply to air performance testing include:
AMCA 210-07, Laboratory Methods of Testing Fans for Aerodynamic Performance Rating.
AMCA 220-05, Test Methods for Air Curtain Units.
AMCA 230-07, Laboratory Methods of Testing Air Circulator Fans for Rating.
AMCA 240-06, Laboratory Method of Testing Positive Pressure Ventilators for Rating.

2)Sound Testing includes:
Inlet sound power.
Outlet sound power.
Total sound power.
Test standards that apply to air performance testing include:
AMCA 300-08, Reverberant Room Method for Sound Testing of Fans.

3)Energy Efficiency Testing includes:
The fans shall be classified for their fan efficiency by using the Fan Efficiency Grade (FEG).
Test standards that apply to air performance testing include:
AMCA 205-10, Energy Efficiency Classification for

AMCO WORLDWIDE CERTIFIED RATINGS SOUND AND ARC PERFORMACE AND AUTOMINAT AND CONTROL AND CO

Fans.

D). 亿利达与 AMCA 国际的关系

1) 亿利达是 AMCA 国际的会员单位。

2) 亿利达建有国内首家 AMCA 标准实验室——按 AMCA 标准建设的全性能实验室。

3) 大部分的产品都通过 AMCA 认证额定值程序 (CRP) 的 测试,相应的样本都获得 AMCA 国际的工作人员批准,这 些产品及其样本已被批准使用 AMCA 国际的认证额定值 印章。

4) 亿利达获得的认证额定值印章,包括:风机的空气性能, 风机的声音,风机效率等级 (FEG)。

注意:

1)有些生产厂商的印刷品中有下列类似阐述"按照 AMCA 标准进行测试",但请注意这与"产品被获准使用 AMCA 国际的认证额定值印章"有本质区别。印有类似语句的印刷品仅仅表明该产品采用 AMCA 公布的标准进行测试,但是其测试的数据不会被 AMCA 承认。

2)另一个容易引致误会的方面是 AMCA 国际的认证额定值印章与 AMCA 会员证书之间的差异。有些生产厂商会将 AMCA 会员证书印在产品目录上,这容易让人误解为其产品已通过 AMCA 的测试及认证。红白的 AMCA 会员证书仅仅代表其为 AMCA 国际的会员,只有蓝黄色和绿黄色的认证额定值印章,才表明该产品是通过 AMCA 认证额定值程序 (CRP)的测试,并被批准使用 AMCA 国际的认证额定值印章。如图 1 所示。

D). Relationship between Yilida and AMCA International, Inc.

1)Yilida is a member of AMCA International, Inc.

- 2)Yilida has build the first AMCA Standard Laboratory in China. The laboratory was built in accordance to the AMCA Standard.
- 3)Most of the products are tested and certified by AMCA Certified Rating Program (CRP), and their catalog ratings are approved by AMCA International's staff. All these products and their catalogs are approved to use the AMCA International Certified Ratings Seal.
- 4)The Certified Rating Seals include: Air Performance, Sound and Fan Efficiency Grade (FEG).

Note:

- 1) Some manufacturers have printed the following statement: "tested in accordance with AMCA standards" in their catalogs. Please note that there are essentially different from the statement of " the products are approved to use the AMCA International Certified Ratings Seal". These manufactures statements mean that their products are tested in accordance with AMCA Standards, but the tested data are not recognized and approved by the AMCA International.
- 2) Another statement that can easily lead to misunderstanding is the difference between the "AMCA Interational Certified Ratings Seal" and the "AMCA Membership Certificate". Some manufacturers have printed the "AMCA Membership Certificate" in their catalogs. This is misleading to let people believe that their products have tested and certified by AMCA. The "AMCA Membership Certificate" (red and white color) indicates that the manufacturer is a member of the AMCA International only. Only the "AMCA International Certified Ratings Seal" (yellow and green, yellow and blue color) symbols indicates that the products have been tested through the AMCA International Certified Rating Program and have been approved to use the "AMCA International Certified Ratings Seal".(Fig.1)



本公司承诺样本中贴有 AMCA 国际的认证额定值印章 的风机,性能都已经通过 AMCA 认证额定值程序 (CRP) 的测试,并被 批准使用 AMCA 国际的认证额定值印章。

Yilida committed that all fans and its catalogs affixed with the AMCA International Certified Ratings Seal. The fans are tested and certified by AMCA Certified Rating Program (CRP) and are approved to use the AMCA International Certified Rating Seal.



风机定律

Fan Laws

该样本中风机性能均指在标准状态下的性能,即风机的气 体状态为:

The fan performance in this catalogue denotes the peformance under the standard air conditions. The standard air conditions are as follows:

空气压力	Air pressure	P = 101.325 kPa
空气温度	Air temperature	t = 20 °C
空气密度	Air density	$\rho = 1.2 \text{ kg/m}^3$

风机定律方程式:

Fan Laws Equations:

$$\frac{q_{V2}}{q_{V1}} = \frac{n_2}{n_1} \times \left(\frac{D_2}{D_1}\right)^3 \qquad \frac{p_2}{p_1} = \left(\frac{n_2}{n_1}\right)^2 \times \left(\frac{D_2}{D_1}\right)^2 \times \left(\frac{\rho_2}{\rho_1}\right) \qquad \frac{P_2}{P_1} = \left(\frac{n_2}{n_1}\right)^3 \times \left(\frac{D_2}{D_1}\right)^5 \times \left(\frac{\rho_2}{\rho_1}\right)^2 \times \left(\frac{$$

应用一:风机转速的变化。 a)当风机尺寸、管网系统及空气密度都不变时,可得: Application 1: Change in Fan Speed. a) When the fan, the airflow system and the air density remain unchanged:

$$\frac{q_{V2}}{q_{V1}} = \frac{n_2}{n_1}$$
 $\frac{p_2}{p_1} = \left(\frac{n_2}{n_1}\right)^2$ $\frac{P_2}{P_1} = \left(\frac{n_2}{n_1}\right)^3$

★ 注:这个定理常用于解决现场风量过大或者风量不足的情况。

例 1: 某工程项目需要一台后向离心风机来送风,风量为 25000 m3/h, 静压为 730 Pa。经选型, 可得风机型号为 SYQ630R, 转速为 1220 r/min, 轴功率为 7.47 kW(电机 功率为 11 kW)。现场要求风量大于原来设计风量,要求风 量增加到 30000 m3/h。

求风机新的转速,静压及轴功率。

E.g. 1: A project needs a backward inclined centrifugal fan to supply air, its airflow is 25,000 m3/h and the static pressure is 730 Pa. After selection, the fan is SYQ630R, the fan speed is 1220 r/min and the shaft power is 7.47 kW (the motor power is 11 kW). Now the site needs to increase the airflow to 30,000m3/h. Find the new fan speed, static pressure and the shaft power.

$$\frac{q_{V2}}{q_{V1}} = \frac{n_2}{n_1} \Rightarrow n_2 = \frac{30000}{25000} \times 1220 = 1464 \ r/min$$

$$\frac{p_2}{p_1} = \left(\frac{n_2}{n_1}\right)^2 \Rightarrow p_2 = \left(\frac{1464}{1220}\right)^2 \times 730 = 1051 \ Pa$$

$$\frac{P_2}{P_1} = \left(\frac{n_2}{n_1}\right)^3 \Rightarrow P_2 = \left(\frac{1464}{1220}\right)^3 \times 7.47 = 12.91 \ kW$$

SYQ630R 风机的最高转速为 1700 r/min。当风机转速提 高到 1464 r/min, SYO630R 的风机能满足要求。 当前风机的轴功率提高到 12.91 kW。原有的 11 kW 电机 已不能满足要求,需更换电机。

The maximum fan speed of SYQ630R is 1700 r/min, so it is not a problem for the fan speed to run 1464 r/min. Now, the shaft power is increased to 12.91 kW, so the original 11 kW motor cannot be used, the motor needs to be changed.

★ 注意: 当现场需要增加风量时,必须注意 (1)风机新的转速不能超过风机的最高转速。 (2) 如原有的电机功率不能满足新的轴功率时,就需要更换电机。

例 2: 在同样的情况下,客户要求增加风量,但不想再投资 去更换电机, 求此 11 kW 电机的条件下, 允许增加多少转 速? 在这个新的转速下,风量和静压是多少?

解: 11 kW 的电机功率减去 10% 的安全系数得轴功率为 9.9 kW。

 $\frac{q_{V2}}{q_{V1}} = \frac{n_2}{n_1} \Longrightarrow q_{V2} = \frac{1340}{1220} \times 25000$

27460 m³/h.

应用二:气体密度的变化。

∴如果不更换电机的情况下,风量只能从 25000 m³/h 增加到

- * NOTE: When the customer site needs to increase the airflow, please pay attention (1) The new fan speed cannot exceed the maximum fan speed.
- (2) If the original motor cannot meet requirement of the new shaft power, then the motor needs to be replaced.

E.g. 2: In the same case, the client requests for additional airflow, but do not want to invest to replace the motor. Under the same 11 kW motor conditions, what is the new fan speed? And in this new speed, what is the airflow and static pressure?

If the safety factor is 10%, the shaft power will be 9.9 kW.

$$\frac{P_2}{P_1} = \left(\frac{n_2}{n_1}\right)^3 \Rightarrow n_2 = \left(\frac{p_2}{p_1}\right)^{\frac{1}{3}} \times n_1 = \left(\frac{9.9}{7.47}\right)^{\frac{1}{3}} \times 1220 = 1340 \text{ r/min}$$

$$\frac{P_2}{P_1} = \frac{1340}{1220} \times 25000 = 27460 \text{ m}^3/\text{h} \qquad \frac{p_2}{p_1} = \left(\frac{n_2}{n_1}\right)^2 \Rightarrow p_2 = \left(\frac{1340}{1220}\right)^2 \times 730 = 881Pa$$

If the motor is not replaced, then the airflow can only be increased from 25000 m3/h to 27460 m3/h.

Application 2: Change in Air Density.

(a)When the fan size, the airflow system and the fan speed remain unchanged:

$$\frac{p_2}{p_1} = \frac{\rho_2}{\rho_1} \qquad \qquad \frac{P_2}{P_1} = \frac{\rho_2}{\rho_1}$$

(b)当风机尺寸,管网系统及压力都不变时;可得;

 $q_{V2} = q_{V1}$

(a)当风机尺寸,管网系统及风机转速都不变时;可得;

(b)When the fan, the airflow system and the pressure remain unchanged

$$p_{2} = p_{1} \Rightarrow \left(\frac{n_{2}}{n_{1}}\right)^{2} = \left(\frac{\rho_{1}}{\rho_{2}}\right) \Rightarrow \left(\frac{n_{2}}{n_{1}}\right) = \left(\frac{\rho_{1}}{\rho_{2}}\right)^{\frac{1}{2}} \qquad \qquad \frac{q_{Y2}}{q_{Y1}} = \frac{n_{2}}{n_{1}} = \left(\frac{\rho_{1}}{\rho_{2}}\right)^{\frac{1}{2}}$$
$$\frac{P_{2}}{P_{1}} = \left(\frac{n_{2}}{n_{1}}\right)^{3} \times \left(\frac{\rho_{2}}{\rho_{1}}\right) = \left(\frac{\rho_{1}}{\rho_{2}}\right)^{\frac{3}{2}} \times \left(\frac{\rho_{2}}{\rho_{1}}\right) = \left(\frac{\rho_{1}}{\rho_{2}}\right)^{\frac{1}{2}} \Rightarrow \frac{P_{2}}{P_{1}} = \frac{q_{Y2}}{q_{Y1}}$$

(c)当风机尺寸,管网系统及空气质量流量(q_)都不变时,可得:

remain unchanged $q_{m_2} = q_{m_1} \implies q_{v_2} \times \rho_2 = q_{v_1} \times \rho_1$

$$\frac{q_{12}}{q_{11}} = \frac{\rho_1}{\rho_2} \qquad \frac{n_2}{n_1} = \frac{\rho_1}{\rho_2} \qquad \frac{p_2}{p_1} = \frac{\rho_1}{\rho_2} \qquad \frac{P_2}{P_1} = \left(\frac{\rho_1}{\rho_2}\right)^2$$

★ 注: 风机样本中的风机性能曲线都是以标准空气为基础的, 这 个定理是用于高海拔高度或高温度的情况,空气密度有变化时, 选择风机的基础。

 $q_m = q_v \times \rho$

(c)When the fan, the airflow system and the mass flow rate (q_)

* Note: The fan performance curves in the catalog are measured under the standard air condition. This application is used for the selection of the fans that running in the high altitude or in the high temperature condition, when there is a change in the air density.



例 3: 某工厂需要一台风机用于排除一个锅炉产生的 20000 m³/h 的 120℃的高温气体,其静压为 450 Pa。求风机所需 的轴功率。

解: 120℃的空气密度 =0.9 kg/m³ 标准空气的密度 =1.2 kg/m³

 $q_{v2} = q_{v1} = 20000 \ m^3/h$ $p_2 = -$

20000 m³/h 风量及静压 600 Pa,标准空气工况选型,得风 机 SYQS900E.转速为 770 r/min,轴功率为 4.93 kW(电 机为 5.5 kW)。 当用于 120℃的高温空气,

∴所需轴功率为 3.7 kW。

应用三:风机尺寸的变化。

 u_2

(a) 当风机转速及空气密度都不变时,可得:

E.g. 3: A factory needs a fan to draw high temperature air from an oven which is delivering 20,000 m³/h of 120 C air against 450 Pa static pressure. Find the shaft power required for the fan. The air density at 120 C = 0.9 kg/ m³ The standard air density = 1.2 kq/m³

 $p_2 = \frac{1.2}{0.9} \times 450 = 600 \ Pa$

Using the airflow 20,000 m³/h and the static pressure 600 Pa, under the standard air condition, the fan selected is SYQS 900E, the fan speed is 770 r/min, the shaft power is 4.93 kW (motor is 5.5 kW). When running at 120 °C high temperature air,

 $P_2 = \frac{0.9}{1.2} \times 4.93 = 3.7 \, kW$

The shaft power required is 3.7 kW.

Application 3: Change in Fan Size.

(a) When the fan speed and the air density remain unchanged:

(b) When the tip-speed of fan and the air density remain

$$= \left(\frac{D_2}{D_1}\right)^3 \qquad \frac{p_2}{p_1} = \left(\frac{D_2}{D_1}\right)^2 \qquad \frac{P_2}{P_1} = \left(\frac{D_2}{D_1}\right)^5$$

(b) 当风机的轮缘线速度及气体密度都不变时。可得:

unchanged:

 q_{V2}

 $q_{\scriptscriptstyle V1}$

$$= u_1 \qquad n_2 D_2 = n_1 D_1 \qquad \therefore \quad \frac{n_2}{n_1} = \frac{D_1}{D_2} \implies \frac{q_{I'2}}{q_{V'1}} = \left(\frac{D_2}{D_1}\right)^2 \qquad \rho_2 = \rho_1 \qquad \frac{P_2}{P_1} = \left(\frac{D_2}{D_1}\right)^2$$

★ 注:这个定理一般为风机设计人员所用,很少用于现场。

例 4: 一家风机制造厂商想把直径为 355 mm 风机的性能 数据扩大应用于直径为 710 mm 的风机。355 mm 风机在 风量 8000 m³/h,静压为 300 Pa 时,它的转速为 784 r/min,轴功率为 1.33 kW。轮缘线速度为 14.57 m/s。对应 一个 710 mm 风机,在相同的转速 (784 r/min)时,求它对 应的风量,静压,轴功率及轮缘线速度。

$$\frac{q_{V2}}{q_{V1}} = \left(\frac{D_2}{D_1}\right)^3 \quad q_{V2} = \left(\frac{710}{355}\right)^3 \times 8000 = 64000 \text{ m}^3/\text{h}$$

$$\frac{P_2}{P_1} = \left(\frac{D_2}{D_1}\right)^5 \qquad P_2 = \left(\frac{710}{355}\right)^5 \times 1.33 = 42.56 \text{ kW}$$

Note: This application is mostly used by the fan designers, it is rarely used at site.

 $= q_{V2}$

E.g. 4: A fan manufacturer wishes to project data obtained for a 355 mm fan to a 710 mm fan. At one operating point, the airflow is 8000 m^3 /h and the static pressure is 300 Pa, the fan speed of the 400 mm fan is 784 r/min, the shaft power is 1.33 kW and its tip-speed is 14.57 m/s.

What will the projected airflow, static pressure, shaft power and tip-speed be for a 710 mm fan at the same fan speed (784 r/min)?

$$\frac{p_2}{p_1} = \left(\frac{D_2}{D_1}\right)^2 \quad p_2 = \left(\frac{710}{355}\right)^2 \times 300 = 1200 \ Pa$$
$$\frac{u_2}{u_1} = \frac{D_2}{D_1} \qquad u_2 = \left(\frac{710}{355}\right) \times 14.57 = 29.14 \ m/s$$

由于不同类型和不同尺寸的风机各有特点,风机制造商必须 制定风机性能曲线。风机性能曲线是风机运转的图形表示, 通常它包括从自由输送(即无阻碍的气流)到无输送(即气流完 全被密封的系统)的全部范围,气体的流量q_v可由以下一个或 多个参数表示:

静压	\mathbf{p}_{sF}	
全压	p _{tF}	
功率	Ρ	
风机青	全妏龟	η.,

风机性

风机全压效率 η_ε

气体密度(ρ)、风机尺寸、以及转速(n)通常在曲线中称为 常量,并应加以标注。

一个典型的风机性能曲线如图2。这些曲线一般均按照适当的 工业测试标准进行实验室试验。例如国际空气运动与控制协 会 (AMCA International)。

风机定律用于在其他转速和风机尺寸时测定轴功率和性能特 点,通常情况下,就如之前提到的,只需测试一个型号风机 的尺寸和转速,就能确定该系列风机的效能。 **Fan Performance Curves**

Since each type and size of fan has different characteristics, fan performance curve must be developed by the fan manufacturers.

A fan performance curve is a graphical presentation of the performance of a fan. Usually it covers the entire range from free delivery (no obstruction to flow) to no delivery (an air tight system with no air flowing). One or more of the following: characteristics may be plotted against volume flow rate (q_v).

Statics Pressure	p _{st}
Total Pressure	p _{tF}
Power	P
Fan Static Efficiency	η _{sE}
Fan Total Efficiency	η,

Air density(ρ), fan size, and fan speed(n) are usually constant for the entire curve and must be stated.

A typical fan performance curve is shown in Fig.2. Generally, these curves are determined by laboratory tests, conducted according to an appropriate industry test standard, e.g. Air Movement and Control Association International Inc.(AMCA). The "Fan Laws" are used to determine the brake horsepower and performance characteristics at other speeds and fan sizes. Normally, as mentioned before, only one fan size and speed must be tested to determine the capacity for a given "family" of fans.



Fig.2 Fan Performance Curve



Fan Basics and Applications 风机基础及应用

系统阻力曲线

System Resistance Curve

1) 管网系统的阻力是指过滤器、冷热盘管、挡板、风阀及管道 1) System resistance is the total sum of all pressure losses 等所有压力损失的总和。系统阻力曲线(图3)仅绘出气体通 过系统所需的压力。

through filters, coils, dampers, and duct work. The system resistance curve (Fig.3) is simply a plot of the pressure that is required to move the air through the system.



图3系统阻力曲线

 $)^2$ $\alpha \lambda^2$ p_{sF} p_{sF}

2) 管网系统的阻力方程:

管网系统所需的功率公式:

$$\frac{q_{V2}}{q_{V1}} = \left(\frac{q_{V2}}{q_{V1}}\right) = \left(\frac{2000}{1000}\right)^2 = \frac{4}{1}$$

2) The pressure equation of a airflow system is:

 $p = k(q_v)^2$

nosition

The power required for the air moving through the airflow system is:

 $P = \frac{1}{30}$

3) 例如,考虑一个 1000 m3/h 的系统,阻力总和为 100Pa。如 果 q, 加倍, p, 静压阻力则将增至 400Pa, 如图 3 中比例的平 方值所示。

4) 但是当过滤器有污物, 盘管开始凝结水分, 或出口调节板改 变了位置时,这时曲线就会有变化。

5) 工况点:图 4 所示的风机在系统中运行的工况点,是由系 统阻力曲线和风机转速性能曲线相交点来确定。每个风机只按 它自己的性能曲线操作,如果原设计系统阻力与安装时的阻力 不同,工况点将会变化,静压和输送风量将与计算不同。

5) Operating point: The operating point (Fig.4) at which the fan and system will perform is determined by the intersection of the system resistance curve and fan performance curve. Note that every fan operates only along its performance curve. If the system resistance designed is not the same as the resistance in the system installed, the operating point will change and the static pressure and volume delivers will not be as calculated.

value of the



图4 工况点

Fig.4 Operating Point



图5系统阳力曲线的变化——风量减少

6) 如果实际系统比预先设计的有更多的阻力损失,因而气体流 量减少,静压增加。(图5) 功率曲线的形状显示轴功率减少。

7) 在很多情况下,风机的实际输出与计算输出之间有差别,它 是由于系统阻力的变化而不是风机或电机的原因。通常是在错 误的交点上获得了静压值,并认为当静压高于设计值时,Q也会 高于设计值,图5显示为何这种假设完全错误的。

Fig.5 Change In System Resistance Curve—Air Volume Reduced

6) If the actual system has more pressure lose than predicted in the design. Such, air volume is reduced and static pressure is increased. (Fig.5) The shape of the kW curve typically would result in a reduction in BKW.

7)In many cases where there is a difference between actual and calculated fan output, it is due to change in system resistance rather than any shortcomings of the fan or motor. Frequently the mistake is made when taking the static pressure reading across the fan and concluding that if the static pressure is at or above design requirements the volume is also at or above design requirements. Fig.5 shows why the assumption is conpletely invalid.



风机振动

Fan Vibration

不平衡的风机在运转时会引起振动,这种振动会使轴承、轴套等 产生过度的磨损,大大降低它们的使用寿命。 振动又会在支座及支架中造成非常不利的交替应力。并最终将 其完全破坏,而且机器的性能也会由于功率被支撑结构吸收而 降低。 此外,振动还可以通过地板传递到邻近的机器,严重地影响其精 度和正常的功能。

引起风机振动的原因有很多种,常见的情况如下:

(a)转子(如风机叶轮、轴或皮带轮等)不平衡
(b)联轴器不对中
(c)基础、支座、支架等刚度不够
(d)风机进口处及出口处的气流不均匀
(e)轴承的润滑油不够等等
其中,引起风机振动最大的原因是转子的动不平衡造成的。

Unbalanced fan can cause vibration during operation. This vibration in turn may cause excessive wear in shafts, bearings, bushings, etc., and greatly reduce their service lives. The vibration will then create a very negative alternating stress in structural supports and frames which may eventually lead to their complete destroy. And the fan's performance will decrease due to the power absorbed by the supporting structure. In addition, the vibration can also be transmitted through the floor to the nearby machines, which can seriously affect their accuracy and proper function.

The fan vibration is caused by a variety of reasons, the commons are as follows:

(a) The unbalanced rotor (eg: fan Wheel, shaft, pulley etc.).
(b) The coupling is misaligned.
(c) The rigidity of the foundation, structural support, frame is not enough.
(d) The uneven airflow passing through the inlet or the outlet of the fan.
(e) Insufficient lubrication of the bearings, and so on.
The main cause of the fan vibration is the unbalanced rotor.

风机的平衡

风机经过动平衡校验的作用是: (a) 提高风机的性能 (b) 减小振动 (c) 减小噪声 (d) 提高轴承的使用寿命 (e) 减少对使用者的干扰及疲劳 (f) 减少能源的损失

Fan Balancing

The effects of the fan trim balancing are: (a) To improve the fan performance (b) To reduce the vibration (c) To reduce the noise (d) To improve the lifetime of the bearings (e) To reduce the fatigue and the disturbance of the operators (f) To reduce the energy losses

转子的平衡精度等级

Balance Quality Grades for Rotors

考虑到技术的先进性和经济上的合理性,国际标准化组织 (ISO)于1940年制定了世界公认的ISO 1940平衡精度等级。 它将转子平衡质量等级分为11个级别,每个等级之间以2.5 倍为增量,平衡机从要求最高的G0.4 到要求最低的G4000。 每个等级的单位为mm/s。

Taking into account the advanced technology and economic rationality, in year 1940, the International Organization for Standardization (ISO) have formulated the Balance Quality Grades for Rotors. The Balance Quality Grades for Rotors is

Grades for Rotors. The Balance Quality Grades for Rotors is divided into 11 grades, each grade is increased by 2.5 times. The balancing machine is requested to balance from the highest grade 60.4 to the lowest grade G4000. The unit of the grade is mm/s.

表 1- 转子的平衡精度等级

Table 1 - Guidance for balance quality grades for rotors in a constant (rigid) state

转子类型举例 Machinery types: General examples	平衡精度等级 Balance quality grade G	振幅 Magnitude eper Ω mm/s
刚性安装的船用柴油机的曲轴驱动件;刚性安装的大型四冲程发动机的曲轴驱动件。 Crankshaft drives of marine diesel engine with rigid installation; Crankshaft drives of large-scale four-stroke engine with rigid installation.	G630	630
刚性安装的高速四缸柴油机的曲轴驱动件。 Crankshaft drives of high-speed four-stroke diesel engine with rigid installation.	G250	250
六缸和多缸柴油机的曲轴驱动件;汽车、货车和机车用的(汽油、柴油)发动机整机。 Crankshaft drives of 6-stroke or multiple- stroke diesel engine. Complete reciprocating; engines for cars, trucks and locamotives(gasoline, diesel oil).	G100	100
汽车车轮、箍轮、车轮整体; 汽车、货车和机车用的发动机的曲轴驱动件。 Cars: wheels, wheel rims, wheel sets, drive shafts; Crankshaft drives of the cars, trucks and lacamotives motor.	G 40	40
粉碎机、农业机械的零件; 汽车、货车和机车用的(汽油、柴油)发动机个别零件。 Components of crushing machines and agricultural machinery; Motor individual component of cars, truck and locomotive(gasoline, diesel oil).	G 16	16
 海轮(商船) 主蜗轮机的齿轮; 离心分离机、泵的叶轮; 风扇; 航空燃气涡轮机的转子部件; 飞轮; 机床的一般零件; 普通电机转子; 特殊要求的发动机的个别零件。 Main turbine gear of seacraft(merchantman); Centrifugal machine, pump Wheel; Fans; Rotors of Aircraft gas turbines; Flywheel; General component of machine-tools; General motor rotor; Individual component of special requirement motor. 	G 6.3	6.3



透平增压器; 机床驱动件;

小电机转子;

Turbo-chargers;

Mechine tool actuator

Minitype motor rotor; Turbine pump.

涡轮泵。

特殊要求的中型和大型电机转子;

从表中,ISO 建议风机的平衡质量等级为 G6.3。 但为了使风机的性能更好,寿命更长久,亿利达风机将内控的平 衡精度等级定位为 G2.5。 In the table, the ISO suggested that the balance quality grade for the fans is G6.3. However, in order to have a better performance and a longer lifetime of the fans, YILIDA has balanced all the fans to a higher grade G2.5.

G 2.5	2.5	

磁带录音机及电唱机驱动件; 磨床驱动件; 特殊要求的小型电枢。 Audio and video drives; Grinding machine drives; Minitype drives with special requirement. 精密唐床的主轴、磨轮及电枢、回转仪。 Spindles and drives of high-precision grinder; drives and gyroscopes.

注1:通常的大部分组长完成的转子是分类的,根据特定的用途,高一个的等级或低一个的等级能用来替换,对于组件,请参阅第九条。

注2:在不指明或不言自明(如曲轴驱动件)的情况下,所有转子都是运转的。

注3:对于因设置条件(平衡机、模具)的限制,请参见5.2中的注4和注5.

燃气和蒸气涡轮,包括海轮(商船) 丰涡轮刚性涡轮发电机转子:

Gas and steam turbine, including ri motor rotor of rigid turbine;

Midsize and large size motor rotor with special requirement;

注4:对于所选的平衡质量等级的其他信息,请参阅图2。基于经验,其包含了普遍的使用范围(使用速度和平衡质量等级G)

注5: 曲轴的驱动器可能包括曲轴,飞轮,离合器,减震器,旋转连杆的部分。原有的不平衡曲轴驱动器理论上可以不均衡;固有的平衡 曲轴驱动器理论上可以平衡。

注6:对于某些机器 ,可能存在具体说明平衡公差的国际标准 (见参考书目)。

NOTE 1 Typically completely assembled rotors are classified here. Depending on the particular application, the next higher or lower grade may be used instead. For components, see Clause 9.

NOTE 2 All items are rotating if not otherwise mentioned (reciprocating) or self-evident (e.g. crankshaft drives).

NOTE 3 For limitations due to set-up conditions (balancing machine, tooling), see Notes 4 and 5 in 5.2.

NOTE 4 For some additional information on the chosen balance quality grade, see Figure 2. It contains generally used areas (service speed and balance quality grade G), based on common experience.

NOTE 5 Crankshaft drives may include crankshaft, flywheel, clutch, vibration damper, rotating portion of connecting rod. Inherently unbalanced crankshaft drives theoretically cannot be balanced; inherently balanced crankshaft drives theoretically can be balanced.

NOTE 6 For some machines, specific International Standards stating balance tolerances may exist (see Bibliography).

平衡机的作用

为了测不平衡量并确定其位置,平衡机是必要的。平衡机所测出 的数据是反映转子的质量分布,由此可以改变转子的质量分布 使转子达到更平衡。

The Purpose of Balancing Machine

A balancing machine is necessary to detect, measure and determine the location of unbalance. The data measured by the balancing machine can be used to change the mass distribution of a rotor. When measuring is done accurately, it can balance the rotor.

允许的剩余不平衡量

Permissible Residual Unbalance

由于任何转子不可能做到 100% 的平衡,因此剩余不平衡量总 是存在的。

一个圆轮的半径为 R(mm),重量为 M(kg),在圆轮上有一超重 点 m(g)。当圆轮旋转时,有一离心力 F 作用在 m 上,并且传递 到圆轮的轴上。结果,轴中心由原来的静止位置产生位移,并围 绕其原来位置形成一个很小的圆。这个位移称为偏心率,见下图 Since it is not possible to have 100% balancing, so there must be some unbalance in tolerance.

A wheel with radius R (mm) and weight M (kg), has a little overweight m (g) at a point. When the wheel is rotating, a centrifugal force F acts upon m and is transmitted to the centre axis. As the result, the axis is displaced from its original position and rotate around its original position to form a small circle. This displacement is called the eccentricity. See below







Fan Vibration and Balancing 风机的振动和平衡



ISO 1940-1:2003(E)

NOTE The white area is the generally used area, based on common experience.

5000

10 000

20 000

100 000

Service speed n, r/min

200 000

50 000

Figure 2-Permissible residual specific unbalance based on balance guality grade G and service speed n (see 6.2)

© ISO 2003 - All rights reserved

In order to ensure that all the fans are running with good performance and long lifetime. Yilida ensures that all its fans are going through 3 types of balancing, each type of balancing has reached the ISO Balance Quality Grades of G2.5. The three types of balance are as follows:



(a) Fan Wheel Balancing

G2.5 before assembly

Every wheel that manufactured by Yilida has to do the

dynamic and static balance, so that each wheel is balanced to

(a)风机叶轮的平衡

亿利达生产的每一个叶轮都要做动、静平衡,使每个叶轮在组装 前达到 G2.5 的平衡等级。



(c)整机的平衡

叶轮、进风口、进风口定位板、电机、底座及减振器等等组装成 整机后,做最后的平衡,达到 G2.5 的平衡等级。平衡后的风 机,电机等在运行时能更稳定。 The wheel, inlet, inlet positioning plate, motor, base of frame, the vibration isolators are assembled together to have a complete fan. The complete fan has to go through the last balance to reach G2.5 balance grade. After balancing that the fan, motor etc will be running more stable.

(c) Complete Fan Balancing



一、概述

声音的本质是波动。受作用的空气发生振动,当振动频率在20-20000Hz 时,作用于人的耳鼓膜而产生的感觉称为声音。声源可以是固体、也可以 是流体(波体和气体)的振动。下面介绍几个与声音相关的物理量。

1) 声功率级

RD

任何一个声源在运转时都会向外辐射声能,在稳定工况下单位时间内辐射的声能称为声功率W,以瓦(W)为单位。通常声学上以声功率级表示,

 $L_{\rm W} = 10 \, \text{lg} \, \frac{W}{W_{\odot}}$

式中 L_W——声功率级,单位为dB; W₀——基准声功率,W₀=10⁻¹²W; W——声功率,单位为W。

2)声强级和声压级

声源的声功率无法直接测定,而使通过测定声源的声压或声强后计算出声 功率。声压P或声强l同样以声压级L_p或声强级L_表示,即

 $L_p = 20 \lg \frac{p}{p_0}$

```
式中 L<sub>0</sub>——声压级,单位为dB;

p.——声压,单位为Pa;

p<sub>0</sub>——基准声压,p<sub>0</sub>=2*10<sup>-5</sup>Pa;该值是对1000Hz的声音人耳刚
能听到的最低声级
```

 $L_1 = 10 \lg \frac{I}{I_0}$

I₀——基准声强,I₀=10⁻¹²W/m²。对于1000Hz的声音,人耳能感觉 到的最小声强约为10⁻¹² W/m²,该基本声强为人的听阈。对于正常人的听 觉所能忍受的声强为Imax=1 W/m²,称为痛阈。

3) 倍频程与声音频谱特性

人类能听到的声音一般指频率为 20-20000Hz 范围内的声波。为了测量方 便,往往将这个频率范围划分成若干个小的频带或频程。在噪声测量中最常 用的是倍频程和 1/3 倍频程。倍频程是指两个相邻频率之比为 2:1 确定的 频程,国际 IEC 规格所规定的常用倍频程如表 1 所表示。1/3 倍频程就是将 一个倍频程再划分为三段。

频谱为声压级或声功率级随着频率的变化的图形,通风机噪声可以粗略地 分为三桨,频谱中最高声压级的中心频率低于500Hz的为低频噪声,最高 声压级的中心频率在500~1000Hz为中频噪声,最高声压级的中心频率大 7 1000Hz 为高频噪声,通风机的频谱一般用频谱分析仪测量得到。

Outlines

The sound is a travelling oscillation. The sound that the human can hear is within the frequency range from 20 Hz to 20,000 Hz. Sound source can be from the vibration of the solid or fluid (liquid and gas).

1) Sound Power Level

The sound power is the sound energy radiated constantly from a sound source. Sound power is expressed in watts (W). Sound power converted to the decibel scale is called sound power level (L_w).

-V ...

where L_w——sound power level, dB W₀——reference sound power, W W——sound power, W

2) Sound Intensity Level and Sound Pressure Level

The sound power from the sound source cannot be directly measured. The sound power is calculated from the sound pressure or the sound intensity that measured from the sound source. Similarly, sound pressure level and sound intensity level are expressed as below:

```
where L_p——sound pressure level, dB

p_{--}—sound pressure, Pa

p_0—reference sound pressure, p_0=2 \times 10-5 Pa,

This value is the minimum sound level at 1,000 Hz that the human ear

can bear
```

where L₁—sound intensity level, dB I—sound intensity, W/m² I₀— reference sound intensity.

This value is the minimum sound intensity that the human ear can feel, and is the human hearing threshold. The maximum sound intensity that the human ear can tolerate is $lmax = 1 \text{ w/m}^2$, it is known as the pain threshold.

3) Octave Bands and Sound Spectrum Characteristics

Normally, human can hear sounds within frequency range from 20 Hz to 20,000 Hz. For the convenient measuring, this frequency range is divided into several small catave bands. The most commonly used in sound measurement is the octave bands and 1/3 octave bands. An octave band is the frequency interval between two sounds whose ratio is 2. Table 1 shown the octave bands from the IEC Standard. 1/3 octave band is an octave band that divided into three portions. Spectrum is the graphics that the sound pressure level or the sound power level changes with the frequency. The sound from a fan can be roughly divided into three categories:

a) The maximum sound pressure level of the center frequency of the band below 500 Hz is called low-frequency noise. b) The maximum sound pressure level of the center frequency of the band within 500 Hz to 1,000 Hz is called medium frequency noise. c) The maximum sound pressure level of the center frequency of the band greater than 1,000 Hz is called high frequency noise.

表 1

频程号 Octave number	1	2	3	;		4		5	6	7	8
中心频率 center frequency/Hz	63	125	25	i0	500		1000		2000	4000	8000
频率范围frequency coverage/Hz	45	90	180	35	55	5 710		1400	2800	5600	11200

018



二、声音的测试方法

Sound Testing Method

声压级和声强级可以用声级计或声强仪进行测定。声级计是常用的 测量仪器, 声强仪的使用目前尚未普及。

除了以上三个衡量声音的基本参数之外,还需要了解声音的频率成 分,这就需要对声音讲行频谱分析。常用的声音频谱为倍频程频谱和 1/3 倍频程频谱。声音频谱由精密声级计或专用的频率分析仪测定。 通过声音频谱的测定,可以分析声源的频率成分,对其采取相应的降 噪措施,使之减少向外辐射的声功率级。

声功率虽然可以由测定声压级的方法间接求得。但是,声压级测定时 往往受到测试环境的影响而不易准确得出,为了使测试环境的影响 降低至最小程度,创造了两种接近理想状态的实验室测试方法:自 由声场法和混响声场法。

声源在一个特定空间内运行时,它所辐射的声能全部为边界所吸收 而没有反射,在这个空间内形成特定的声波传播规律。这个特定空间 称之为自由声场。模拟自由声场的实验室常用的是全消声室或半消 声室。反之,若这个特定空间的边界是全反射而无声能的吸收,同样 在此特定空间内也存在特定的声波传播规律。这个特定空间称之为 混响声场,模拟混响声场的实验室常用的是混响室。

这里主要介绍下混响室法。

如果在以封闭的空室(混响室)内设置以声源,经过一段时间后,在该室内产生 —— 恒定的 吉 压级 .

在切断声源后,声音并不立即消失,储存在空间的声能逐渐衰减,这一过程为 扩散声场或混响声场。混响时间定义为声能密度衰减到 60dB(即原有值的 10-6倍)所需的时间。

在混响室中,测量充分扩散的声场,称为扩散声场法。若扩散声场的平均声压 级为 L.,则相应的声功率级为

$$L_W = L_P + 10 \lg V - 10 \lg T - 14$$
 (dB)

式中: V 为混响室容积(m³); T 为混响时间(s)。 如果测量充分扩散的声场, 而混响室的房间常数为 R, 测量充分扩散的声场 声压级为 L_,相应的声功率级为;

$$L_W = L_P + 10 \lg R - 6 \quad (\text{dB})$$
single R = $\frac{\alpha S}{1 - \alpha^2} (m^2)$

式中: R 为混响室的房间常数

其中, α 为吸声系数, 一般 α =0~1.0; S 为混响室的表面积。

事实上,实验室的边界对所有频率不可能做到完全吸收或完全反射,这种差异 性规定了在实验室测定声功率级的精度要求(对声压级来说即为允许偏差的 要求),这就必须有一个统一的测试规定即测试方法的标准。这里有两种,一种 是以国际标准化组织指定的标准 (即 ISO 标准);另一种是美国 AMCA 或 ASHRAE 指定的标准属于行业性质的标准。两者的标准之间是存在一些区 别的。

亿利达风机实验室所建的混响室与气动性能实验室结合在一起的风机测试实 验室,属国内首创,符合 AMCA300-96《风机声学测试——混响室法》的有关 要求和规定。

Sound pressure level and sound intensity level can be measured from the sound level measuring meter or the sound intensity meter. Besides the three basic parameters of the sound, it is important to understand the sound frequency which will have to analyze the sound spectrum. The sound spectrum can be measured from the sound frequency analyzer. From the analysis of the sound spectrum, the sound level can be reduced and the radiation of the sound power level can also be reduced.

The sound power can be determined indirectly from the measuring of the sound pressure level. However the sound pressure level is not easy to measure, as it is influenced by the effects of the testing environment. In order to minimize the impact of the testing environment, two ideal state of the laboratory testing methods are created, free field method and reverberant field method.

When sound source is running in a given space, all the sound energy radiated from the sound source is absorbed by the boundary without reflection, and form a specific propagation of the sound waves in this space. This particular space is called the free field. The laboratory that simulates the free field is normally used full-anechoic room or semi-anechoic room. Conversely, if the sound energy is totally reflected by the boundary of this particular space with no absorption, and it forms another specific propagation of the sound waves in this space. This particular space is called the reverberant field. The laboratory that simulates the reverberant sound field is normally used the reverberant room

Below is the introduction of the reverberant room. A sound source is set in a closed room (reverberant room), after a time a constant sound pressure level is produced in the room. In this stable state, if ignored the loss of the sound power due to the absorption of the air and the wall surround, the sound power is equal to the sound power releases from the sound source. This process is the direct sound field. After switching off the sound source, the sound does not disappear immediately, The sound energy in the room is gradually attenuated, this process is the diffuse sound field or the reverberant sound field. The . reverberation time is defined as the time required to let the sound energy density attenuate to 60 dB (i.e. 10 to 6 times the original value). In the reverberant room, measuring the full diffusion of the sound field is known as the diffuse sound field method. The sound power level is corresponding to the average sound pressure level Lp in the diffuse sound field as follow

Where V ----- the volume of the reverberant room (m3) T ----- the reverberation time (s). If the reverberant room constant is R and the sound pressure level measured in the full diffusion of the sound field is L, then the corresponding sound power level is :

Where R ----- the reverberant room constant α ----- the absorption coefficient, normally $\alpha = 0 \sim 1.0$ S ----- the surface area of the reverberant room.

In fact, all the sound frequencies can not be totally absorbed or reflected by the boundaries of the laboratory, this difference provides the accuracy requirement the sound power level measurement in the laboratory (it is the allowable deviation requirement of the sound pressure level). So, the test must have a unitary standard for the sound testing methods. There are two standards, one is the ISO standards, and the other is the AMCA or ASHRAE standards. There are some differences between the two standards

Yilida's comprehensive fan performance test laboratory has a reverberant room and an aerodynamic performance lab. This reverberant room is built in according to the requirements and the regulations of AMCA 300-96 (Reverberant Room Method for Sound Testing of Fans).

三、声音的计算

如前所述,当声音信号进入A计权网络时,低频的声音按比例衰减 通过,而 1000Hz 以上的声音无衰减地通过。这种被 A 网络计权 后的声压级,就称为 A 声级 L。。它的单位为 dB。A 声级可以直接 测量,也可以由8个倍频程声压级计算得到,其数学表达式为:

$$L_{\rm A} = 10 \log \sum_{i=1}^{8} 10^{0.1 (L_{\rm pi} + \Delta A_i)}$$

L_a——倍频程声压级,单位为dB; 式中

表8个倍频程中心频率63,125,250,500,1000,2000,4000,8000Hz。

Where	L _{ai} octave band sound pressure level, in dB
	Ai weighted attenuated value, refer to table 1, in which
i=1,2,	, 8 represent the 8 octave band centre frequency 63, 125,
250, 50	0, 1k, 2k, 4k, 8k Hz.

As mentioned earlier, when the sound signal enters the A

weighting network, the low-frequency sound will attenuate

proportionally through the network. The sound pressure level

that was adjusted by A weighting network is called A-weighted

sound level L., its unit is dB(A). The A-weighted sound level

can be measured directly, can also be calculated from the 8

octave bands of the sound pressure level. Its expression is:

Sound Calculation

中心频率 Center frequency/Hz	63	125	250	500	1000	2000	4000	8000
计权衰减值 Weighted attenuated value ^{/Hz}	-26	-16	-9	-3	0	1	1	-1

通风机的 A 声级不仅与风机尺寸大小与转速有关, 而且还取决于流 量和压力的大小。为了比较不同型号及不同性能参数的通风机的噪 声特性,可以引入比 A 声级 L。, 通风机测试工况点比 A 声级的数 学表达式:

$$L_{sA} = L_A - 10 lg (q_V p_{tF}^2) + 19.8$$

式中 L_{sa}——通风机测试工况点的比 A 声级,单位为 dB(A); L_____通风机测试工况点的 A 声级,单位为 dB(A); q,_____通风机测试工况点流量,单位为 m³/min; p____通风机测试工况点全压,单位为 Pa。 目前国内指定的通风机噪声标准都采用比 A 声级来评价通风机的噪声特性。

在实际工作中进行声音叠加时,可查曲线值来计算。见图 1。 两个噪声相加, L。,,=L,1+L,2,规律总结如下: a) 总声压级不会比其中任一个大3分贝以上; b) 两个声压级相差 10 分贝以上时,叠加增量可忽略不计。 c)两个声压级相差10分贝以下时,查表确定增加量,再与大的叠加。 d) 对于多个声源,只需两两逐次叠加即可,和顺序没有关系。



The A-weighted sound level of the fans is not only related with the fan size and the fan speed, but also depended on the air flow-rate and the pressure. In order to compare the sound characteristics of different models and different performance parameters, the specific A-weighted sound level Les is introduced. The specific A-weighted sound level is expressed as:

Where L_{sa} ----- the specific A-weighted sound level, in dB(A)

- L, ----- the A-weighted sound level, in dB(A)
 - q., ----- the air flow-rate, in m3/min

p, ----- the total pressure in Pa.

At present, the fan noise standards are using the specific A-weighted sound level to evaluate the noise characteristics of the fans.

In actual work, when the sounds are combining, the curve shown in Figure 1 can be used to calculate the value of the combined sounds

When two sounds are combined, $L_{ototal} = L_{o1} + L_{o2}$, the rules are as follow:

a) The total sound pressure level is no more than any of the two sound pressure level by 3 dB.

b) If the difference of the two sound pressure level is equal to. or more than 10 dB, the increment is negligible. c) When the difference of the two sound pressure level is less

than 10 dB, then find the increment from the table, and add to

d) For more than two sound sources, just combine any two sound pressure level each time until the finished sound. pressure level is calculated, the sequence does not matter.



四、通风机噪声产生的原因	The Causes of the Noise Generated	一、选择风机的原则	The Principle of Fan Selection
通风机的噪声主要包括空气动力所产生的噪声、机械振动所产生的 噪声和两者共同作用产生的噪声3个方面。 1)空气动力所产生的噪声 (a)冲击噪声 叶轮高速旋转时,叶片作周期性运动,空气质点受到周期性力的作 用,冲击压强波以声速传播所产生的噪声。 (b)涡流噪声 叶轮高速旋转时,风气体边界分离而产生的涡流所引起的噪声	There are three causes of the fan noise generated: aerody- namic, mechanical vibration, between the aerodynamic and the vibration. 1) The noise generated by aerodynamic (a) The impact noise When the Wheel is rotating at a high speed and the blade is moving periodically, the air particle is affected by the periodic force, that pushes the pressure waves at the sound speed to generate noise.	风机选型时,首先要确定系统所需的流量和压力。由于风机样本中 流量和压力等性能参数通常都是以标准大气状态下给出的,所以 须将使用条件(如输送气体的温度、密度、工作点海拔高度或大气 压力等)下系统所需的流量、压力等参数换算到标准大气状态,依 此选择风机。 通风机的标准大气状态,通常是指在海拔高度0m,温度20℃,大 气压力101.325 kPa时,输送相对温度50%,密度1.2 kg/m ³ 的 空气。	First, we must determine the airflow and the pressure in the system. As the fan performance data in the catalog are usually given in the standard conditions, all the data of the operating point in the system must be converted to the standard atmospheric conditions before selection. The standard atmospheric conditions are referred to altitude 0 m, temperature 20 $^\circ$, atmospheric pressure 101.325 kPa, air density 1.2 kg/m ³ .
2) 机械振动性噪声	(b) lumbulancel Noise When the Wheel is rotating at a high speed, there may have a swirl occurred at the inlet of the fan, then a noise is generated	二、温度和海拔高度对空气的影响	The Effects of Temperature and Altitude
回转体的不平衡及轴承的磨损、破坏等原因所产生的振动必然会产 生噪声,当叶片刚性不足,气流作用使叶片振动,也会产生噪声。 3)两者相互作用而产生的噪声 叶片旋转引起自身振动通过管道传递,往往在管道弯曲部发生冲击 和涡流,造成振动加剧使噪声增大,特别是当气流压强声波的频率与 管道自身振动相同时,将产生强烈的共振,噪声会突然增大,严重时	due to turbulance. 2)The noise from the mechanical vibration The unbalance Wheel, the damaged bearing and others will cause vibration. The vibration will generate noise. If the blade is not rigid enough, it will vibrate when rotating that will also generate noise. 3)The noise generated from the interaction between the aerody-	但是在实际选型过程当中,有些风机的应用场合分布在不同的海拔 和温度环境下,此时气体的密度随之影响很大。 1)海拔高度对大气压力的影响,可用以下公式表示: $p_1 = p_0 \times (0.885)Z \div 1000$	Some fans are used in a high altitude and different temperature conditions, where the air density will vary accordingly. The effects of the temperature and the altitude must be considered, when doing selection. 1)The effect of the altitude to the atmospheric pressure can be expressed as the following formula:
将导致通风机破坏。	namic and the vibration Vibration caused by the rotating blades and transmitted through the duct, then occur impact and swirl in the bending of the duct that increase the vibration and increase the noise. Especially when the air pressure wave frequency is same as the vibration	注: p,实际空气状态下压力; p,标准状态下压力; Z海拔高度。	Note: p ₁ actual atmospheric pressure, p ₀ standard atmospheric pressure, Z altitude.
	frequency of the duct that cause a strong resonance, then the noise suddenly increases. It can result in serious damage to the face.	2) 而温度根据工况点的实际情况定,温度及大气压力对大气密度 的影响,可由下列公式表示:	2)The effects of the temperature and the atmospheric pressure to the air density can be expressed as the following formula:
	lall.		
五、通风机噪声的控制	The Control of the Noise of the Fans	$\rho_{f} = \rho_{0} \left(\frac{p_{I}}{p_{0}} \times \frac{273 + t_{0}}{273 + t_{I}} \right)$	where : $\rho_p=1.2\text{kg/m}^3$ —— air density in the standard atmospheric condition
五、通风机噪声的控制 1)设计良好的通风机 在设计时,为了防止或减少本身噪声源的产生,应尽量减少气流的 冲击,避免尖锐突出和流道的急剧转弯。合理选择风机的转速大小, 注意控制叶轮和蜗舌的间隙,此间隙越小,噪声越大。	 The Control of the Noise of the Fans 1)Well-designed of Fans When design the fans, in order to prevent or reduce the generation of the sound source, should minimize the impact of the air flow, the side plate and the scroll must be smooth without uneven prominent, and avoid the sharp turn of the air flow. The fan speed must be selected correctly, and the gap between the cutoff and the wheel must be controlled, as the smaller the gap, the greater the noise. 	$\rho_{t} = \rho_{0} \left(\frac{p_{I}}{p_{0}} \times \frac{273 + t_{0}}{273 + t_{I}} \right)$ $ \vec{x} \oplus \left[p_{0} \oplus 1.2 \text{ kg/m} \oplus \overline{w} \# \pm (\vec{x} \pm \vec{n}) \oplus \vec{n} \oplus 1.325 \text{ kPa} \oplus \overline{w} \# \pm (\vec{x} \pm \vec{n}) \oplus \vec{n} \oplus 1.325 \text{ kPa} \oplus \overline{w} \# \pm (\vec{x} \pm \vec{n}) \oplus \vec{n} \oplus 1.325 \text{ kPa} \oplus \overline{w} \# \pm (\vec{x} \pm \vec{n}) \oplus \vec{n} \oplus 1.325 \text{ kPa} \oplus \overline{w} \# \pm (\vec{x} \pm \vec{n}) \oplus \vec{n} \oplus 1.325 \text{ kPa} \oplus \overline{w} \# \pm (\vec{n} \oplus 1.325 \text{ kPa} \oplus 1.325$	where: $p_0=1.2kg/m^3$ air density in the standard atmospheric condition, $p_0=101.325kPa$ standard atmospheric pressure, $t_0=20$ C temperature in the standard atmospheric condition, p1, $p1$, $t1$
 五、通风机噪声的控制 1)设计良好的通风机 在设计时,为了防止或减少本身噪声源的产生,应尽量减少气流的 冲击,避免尖锐突出和流道的急剧转弯。合理选择风机的转速大小,注意控制叶轮和蜗舌的间隙,此间隙越小,噪声越大。 2) 消声器 消声器一般可以通过吸收噪声源和进出风口产生的噪声来隔音降噪。不同类型的风机用的消声器各有不同。 	 The Control of the Noise of the Fans 1)Well-designed of Fans When design the fans, in order to prevent or reduce the generation of the sound source, should minimize the impact of the air flow, the side plate and the scroll must be smooth without uneven prominent, and avoid the sharp turn of the air flow. The fan speed must be selected correctly, and the gap between the cutoff and the wheel must be controlled, as the smaller the gap, the greater the noise. 2)Silencer Silencer can generally absorb the sound source and the noise generated from the inlet and the outlet of the fans. Different types of fans will use different kind of silencers. 	$\begin{split} \rho_{f} &= \rho_{0} \Big(\frac{p_{I}}{p_{0}} \times \frac{273 + t_{0}}{273 + t_{I}} \Big) \\ \text{interms } \rho_{0} = 1.2 \text{ kg/m}^{3} &\longrightarrow \text{ fract} \text{fixability} -$	where : $p_0=1.2kg/m^3$ — air density in the standard atmospheric condition, $p_1=101.325kPa$ — standard atmospheric pressure, $t_0=20$ C — temperature in the standard atmospheric condition, p1, p1, t1 — actual atmospheric pressure, air density and temperature. 3)If then: e — the correction factor of air density.
五、通风机噪声的控制 1)设计良好的通风机 在设计时,为了防止或减少本身噪声源的产生,应尽量减少气流的 冲击,避免尖锐突出和流道的急剧转弯。合理选择风机的转速大小,注意控制叶轮和蜗舌的间隙,此间隙越小,噪声越大。 2) 消声器 例 声器 例 可以通过吸收噪声源和进出风口产生的噪声来隔音降噪。不同类型的风机用的消声器各有不同。	 The Control of the Noise of the Fans 1)Well-designed of Fans When design the fans, in order to prevent or reduce the generation of the sound source, should minimize the impact of the air flow, the side plate and the sorroll must be smooth without uneven prominent, and avoid the sharp turn of the air flow. The fan speed must be selected correctly, and the gap between the cutoff and the wheel must be controlled, as the smaller the gap, the greater the noise. 2)Silencer Silencer can generally absorb the sound source and the noise generated from the inlet and the outlet of the fans. Different types of fans will use different kind of silencers. 	$\begin{split} \rho_{t} &= \rho_{0} \Big(\frac{p_{I}}{p_{0}} \times \frac{273 + t_{0}}{273 + t_{I}} \Big) \\ \vec{x} \oplus : \rho_{0} &= 1.2 \text{ kg/m} & \forall \text{watch} = \forall \text{watch} = 1.2 \text{ kg/m} & \forall \text{watch} = \forall \text{watch} = 1.2 \text{ kg/m} & \forall \text{watch} = \forall \text{watch} = 1.2 \text{ kg/m} & \forall watch$	where: $p_a=1.2\text{kg/m}^3$ idensity in the standard atmospheric condition, $p_a=101.325\text{kPa}$ standard atmospheric pressure, $t_a=20$ C temperature in the standard atmospheric condition, p_1, p_1, tf actual atmospheric pressure, air density and temperature. 3) If then: e the correction factor of air density. $\therefore \frac{p_1}{p_0} = (0.885)Z \div 1000$
五、通风机噪声的控制 1)设计良好的通风机 在设计时,为了防止或减少本身噪声源的产生,应尽量减少气流的 体击,避免尖锐突出和流道的急剧转弯。合理选择风机的转速大小,注意控制叶轮和蜗舌的间隙,此间隙越小,噪声越大。 2) 消声器 3) 消声器 满声器一般可以通过吸收噪声源和进出风口产生的噪声来隔音降 噪。不同类型的风机用的消声器各有不同。	 The Control of the Noise of the Fans 1)Well-designed of Fans When design the fans, in order to prevent or reduce the generation of the sound source, should minimize the impact of the air flow, the side plate and the scroll must be smooth without uneven prominent, and avoid the sharp turn of the air flow. The fan speed must be selected correctly, and the gap between the cutoff and the wheel must be controlled, as the smaller the gap, the greater the noise. 2)Silencer Silencer can generally absorb the sound source and the noise generated from the inlet and the outlet of the fans. Different types of fans will use different kind of silencers. 	$\begin{split} \rho_{t} &= \rho_{0} \Big(\frac{p_{t}}{p_{0}} \times \frac{273 + t_{0}}{273 + t_{t}} \Big) \\ \text{i.t.} &: p_{0} = 1.2 \text{ kg/m}^{3} \longrightarrow \text{frack} = \text{frack} \text{frack} \text{frach} frach$	where: $p_{c}=11.2$ kg/m ³ — air density in the standard atmospheric condition, $p_{1}=101.325$ kPa— standard atmospheric pressure, $t_{0}=20$ C— temperature in the standard atmospheric condition, p_{1} , p_{1} , t_{1} —actual atmospheric pressure, air density and temperature. 3) If then: e— the correction factor of air density. $\therefore \frac{p_{1}}{p_{0}} = (0.885)Z \div 1000$ then:



大气密度的修正系数表 Atmospheric density correction factor table

气温で	海坂 Altitude (单位:m)															
Temperature	0	400	800	1200	1600	2000	2400	2800	3200	3600	4000	4400	4800	5200	5600	6000
- 40	1.26	1.20	1.14	1.09	1.04	0.99	0.94	0.89	0.85	0.81	0.76	0.73	0.69	0.65	0.62	0.59
- 20	1.16	1.11	1.05	1.00	0.96	0.91	0.87	0.82	0.78	0.74	0.70	0.67	0.64	0.60	0.57	0.54
0	1.07	1.03	0.98	0.93	0.89	0.84	0.80	0.76	0.73	0.69	0.65	0.62	0.59	0.56	0.53	0.50
20	1.00	0.96	0.91	0.87	0.83	0.78	0.75	0.71	0.68	0.64	0.61	0.58	0.55	0.52	0.49	0.47
40	0.94	0.89	0.85	0.81	0.77	0.73	0.70	0.67	0.63	0.60	0.57	0.54	0.51	0.49	0.46	0.44
60	0.88	0.84	0.80	0.76	0.73	0.69	0.66	0.63	0.59	0.56	0.54	0.51	0.48	0.46	0.43	0.41
80	0.83	0.79	0.76	0.72	0.69	0.65	0.62	0.59	0.56	0.53	0.51	0.48	0.46	0.43	0.41	0.39
100	0.79	0.75	0.71	0.68	0.65	0.62	0.59	0.56	0.53	0.50	0.48	0.45	0.43	0.41	0.39	0.37
140	0.71	0.68	0.65	0.62	0.59	0.56	0.53	0.50	0.48	0.46	0.43	0.41	0.39	0.37	0.35	0.33
180	0.65	0.62	0.59	0.56	0.53	0.51	0.48	0.46	0.44	0.42	0.39	0.37	0.35	0.34	0.32	0.30
220	0.59	0.57	0.54	0.52	0.49	0.47	0.44	0.42	0.40	0.38	0.36	0.34	0.33	0.31	0.29	0.28
260	0.55	0.53	0.50	0.48	0.45	0.43	0.41	0.39	0.37	0.35	0.33	0.32	0.30	0.29	0.27	0.26
300	0.51	0.49	0.47	0.44	0.42	0.40	0.38	0.36	0.35	0.33	0.31	0.30	0.28	0.27	0.25	0.24
350	0.47	0.45	0.43	0.41	0.39	0.37	0.35	0.33	0.32	0.30	0.29	0.27	0.26	0.24	0.23	0.22
400	0.44	0.42	0.40	0.38	0.36	0.34	0.33	0.31	0.29	0.28	0.27	0.25	0.24	0.23	0.21	0.20
450	0.41	0.39	0.37	0.35	0.33	0.32	0.30	0.29	0.27	0.26	0.25	0.23	0.22	0.21	0.20	0.19
500	0.38	0.36	0.35	0.33	0.31	0.30	0.28	0.27	0.26	0.24	0.23	0.22	0.21	0.20	0.19	0.18
‡. 当实[,当实际温度或海拔高度不在表中时,可进行教坛的话值计算 表 1															

Fia 1

注: 当实际温度或海拔高度不在表中时,可进行数据的插值计算 Note: When the actual temperature or altitude is not on the table, the data can be interspersed calculation

例 1: 某化工行业项目在海拔 0 米,平均气温 10℃的环境需要一 台双进风后向离心风机来送风,客户要求的是质量流量为 12000 kg/h,静压为 500 Pa。

解:当具体风机选型时,需考虑两方面因素,一方面是所给流量参数 是质量流量(单位是 kg/h)还是体积流量(单位是 m³/h);如果给的 是体积流量那就按实际值计算。如果给的是质量流量,那要转化成体 积流量。一般情况下默认是体积流量。

第二方面考虑的内容压力 P。当一定的风机尺寸和一定转速,密度发 生变化时,所有压力变化与密度成正比,功率和密度也是成正比的。

通过查表可得海拔0米,气温10℃时密度系数e为1.07。 转化到标准大气状态下: E.g. 1: A chemical factory which is located at an altitude 0 m and average temperature 10 C place needs a DIDW centrifugal fan to supply air. The required mass flow rate is 12000 kg/h and the static pressure is 500 Pa.

Before selection, the following must be considered: First, if the flow rate given is mass flow rate, then convert the mass flow rate to the volume flow rate. Second, when there is a difference in the air density, the pressure p must be converted to the pressure in the standard atmospheric condition.

From the table, at altitude 0 m and temperature 10 $\rm {C}$, the corrective factor of the air density e is 1.07. Convert to standard atmospheric condition:

$$q_{VI} = \frac{q_{m1}}{\rho_{T}} \quad \rho_{1} = \rho_{0} \times e \quad \therefore \quad q_{VI} = \frac{q_{mI}}{\rho_{0} \times e} = \frac{12000 \ kg/h}{1.2 \ kg/m^{3} \times 1.07} = 9346 \ m^{3}/h$$

因为在一定的风机尺寸和一定的转速,密度变化时:流量不受影响。

Because the volume flow rate is unchanged when the air density is changing, but the fan diameter and rpm are not changing.

$$\therefore q_{V0} = q_{V1} = 9346 \ m^3/h$$

$$\frac{p_1}{p_0} = \frac{\rho_1}{\rho_0} = e \qquad \therefore \ p_0 = p_1 \div e = 500 \, Pa \div 1.07 = 467 \ Pa$$

选型可得风机型号为 SYD450K, 风机转速 735 r/min,风机轴功率为 1.824 kW,电机功率为 2.2 kW。

From the above data, the fan selected is SYD 450 K, fan speed is 735 r/min, shaft power is 1.824 kW and the motor power is 2.2 kW.

此前一直正常运行,随着进入夏季,该厂在实际生产中发现风机性 能达不到要求,于是找到生产厂家寻求解决办法。

解:通过询问该厂的环境情况得知,目前该厂最高温度在 40℃; 通过查表可得海拔 0 米,气温 40℃时密度系数 e 为 0.94。 转化到标准大气状态下: In summer, the client find that the air flow does not meet the requirement, so he calls for help.

Knowing that the temperature now is 40 C, from the table, at altitude 0 m and temperature 40 C, the corrective factor of the air density e is 0.94. Convert to standard atmospheric condition:

$$q_{VI} = \frac{q_{m1}}{\rho_t}$$
 $\therefore q_{VI} = \frac{q_{mI}}{\rho_0 \times e} = \frac{12000 kg/h}{1.2 kg/m^3 \times 0.94} = 10638 m^3/h$

同理可得:

$$q_{V0} = q_{V1} = 10638 \text{ m}^3/\text{h}$$

$$\frac{p_1}{p_0} = \frac{\rho_1}{\rho_0} = e \quad \therefore \quad p_0 = p_1 \div e = 500 Pa \div 0.94 = 532 \ Pa$$

选型可得风机型号为 SYD450K, 风机转速 775 r/min,风机轴功 率为 2.323 kW,电机功率为 3 kW。针对这种温度变化,使用者对 风量要求比较严格的情况:建议使用 3 KW 的变频电机,变频调 节风机转速或者配 3 KW 的普通电机再配上风量调节阀来控制。

例 1:某工程项目在海拔 800 米,气温 60℃的环境需要一台单进 风后向离心风机来送风,风量为 20000m³/h,静压为 900Pa。请选 型。

解:通过查表可得海拔 800 米,气温 60℃时密度系数 e 为 0.80。 转化到标准大气状态下:

$$\frac{p_1}{p_1} = \frac{\rho_1}{p_1} = e \quad \therefore \quad p_0 = p_1 \div e = 900Pa \div 0.80 = 1125Pa$$

压力按 1125 Pa 选型可得风机型号为 SYQS900E, 风机转速 933 r/min,风机轴功率为 8.124 kW,电机功率为 11 kW。可后来 根据实际需要又将设备移到海拔 3000 m 的环境下使用,发现此 时静压不够,求解决问题的方法。

 $p_0 \quad \rho_0$

解:通过查表可得海拔 3200 米,气温 60℃时密度系数 e 为 0.59。 转化到标准大气状态下: From the above data, the fan selected is SYQS 900 E, fan speed is 933 r/min, brake horsepower is 8.124 kW and the motor power is 11 kW. After some times, the fan is moved to a location at altitude 3200 m and temperature 60 C, then find that the static pressure is not enough for the operating. Find the solution.

From the data above, the fan selected is SYD 450 K, fan speed

power is 3 kW. For this project, the air mass flow rate must be

constant, so it is recommended to use 3 kW motor. By using the

VFD to change the motor speed or using damper to control the

E.g. 2: A project which is located at altitude 800 m and average temperature 60 °C place requires a single inlet backward

inclined centrifugal fan to supply air. The air volume is 20000

From the table, at altitude 800 m and temperature 60 °C, the

m3/h and the static pressure is 900 Pa.

corrective factor of the air density e is 0.80.

Convert to standard atmospheric condition:

air volume, to ensure that the air mass flow rate is constant.

is 775 r/min, brake horsepower is 2.323 kW and the motor

From the table, at altitude 3200 m and temperature $60\,{\rm C}$, the corrective factor of the air density e is 0.59. Convert to standard atmospheric condition:

$$\frac{p_1}{p_0} = \frac{\rho_1}{\rho_0} = e \quad \therefore \quad p_0 = p_1 \div e = 900Pa \div 0.59 = 1525 Pa$$

压力按 1525 Pa 选型可得风机型号为 SYQS900E,风机速 1061 r/min,风机轴功率为 11.35 kW,电机功率为 15 kW。此时 需要更换电机和皮带轮才能满足工况需求。 From the above data, the fan selected is SYQS 900 E, fan speed is 1061 r/min, brake horsepower is 11.35 kW and the motor power is 15 kW. So, to solve the problem, the motor and the drive package must be changed to satisfy the requirement.



WPH SERIES WPH 系列风机产品说明 The WPH Series Roof Fan

Roof Fan

WPH SERIES WPH 系列风机产品说明 The WPH Series Roof Fan

WPH 屋顶风机

浙江亿利达风机股份有限公司特此证明,此处所示WPH系列屋顶风机获得了加盖 AMCA印章的授权。所示额定值系根据AMCA出版物211和AMCA出版物311所 进行测试和程序确定,并符合AMCA认证额定值计划的要求。 这里描述的所有屋顶风机都已经取得了AMCA印章,其认证数据见第031页到043页。

Zhejiang Yilida Ventilator Co.,Ltd. certifies that the WPH Roof fans shown herein are licensed to bear the AMCA Seal.The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 211 and AMCA Publication 311 and comply with the requirements of the AMCA Certified Ratings Program. All the Roof Fans described herein are licensed to bear the AMCA Seal, and their certified ratings are shown on pages 031 through 043.



屋顶风机按所配风机形式分为离心式和轴流式两大类;离心式屋顶风机是我公司在国内率先采用开发的无蜗壳风机的高效叶轮,配合航空级高强度合金铝材质机壳设计而来。产品结构紧凑、外形美观、气体流动均匀;风机可以安装在各种屋顶,可接圆形或方形法兰或泛水安装。是厂房屋顶排风的首选产品。

Summary

The Roof fan is divided into two types: centrifugal type and axial type; centrifugal roof fan is using the plug fan impeller with high-strength aircraft-grade aluminum alloy casing. Compact structure, beautiful shape, the air flow smooth; fan can be installed in a variety of roofs, which can be accessed round or square flange or flashing installation. These fans are ideal for factory roof discharge.

命名方式

概述

WPH EX 355 - 2 / 2 电机级数 电机功率(kW) 中轮直径(mm) EX=防爆功能 H=Y2系列普通电机 类型 P=圆形 G=方形 屋顶风机

Motor poles Motor Power (kW) Diameter of Impeller (mm) Explosion Proof Y2 series Motor Type P = Round G = Square

Nomenclature

Roof Fan

产品结构

WPH系列风机主要由机壳、叶轮、电机、防鸟网和挡水板、自垂百叶等构成。

1. 机壳

屋顶风机机壳采用航空级高强度合金铝拉伸或折弯而成,有效降低自重。进风口和底板整体拉伸成型,使得整体结构紧凑、外形美观、气体流动均匀,而且完全避免了风机底板的渗水的问题。

Product Features

WPH Series fans mainly consist of the housing, impeller, motor, safty net, eliminator and gravity shutter, since the vertical blinds and other accessories.

1. Housing

Roof fan housing uses high-strength aircraft-grade aluminum alloy made of stretching or bending, reduce weight. Inlet and the baseplate are made of stretching forming, for compact structure, beautiful shape, smooth airflow, and completely avoiding the problem of water creep.





WPH SERES WPH 系列风机产品说明 The WPH Serie & SoofFan

产品结构

2. 叶轮

后向铝合金叶轮,采用无叶扩压技术,有效提高风机效率。叶 轮轮毂采用锥套锁紧的方式,叶轮和电机采用无间隙配合,最 大限度的减少了由于叶轮轮毂和电机轴配合造成的装配误差, 避免了平衡的破坏,提升了平衡等级。

3. 电机

WPH系列风机标配电机的绝缘等级为F级,防护等级为IP54 连续运转的温度范围为 −20℃~ +40℃,其它的运行条件见 要求。

4. 防鸟网和挡水板

WPH系列风机采用优质不锈钢铁丝网,C型挡水铝板防锈耐腐蚀,安全可靠。

5.自垂百叶

优质铝合金材质的百叶装在泛水中,尺寸可根据泛水大小定。有 效的防止气流倒灌。

很多屋顶送风机未设置停机后防止空气倒流的装置,或是屋顶风 机停机后阀门不能可靠关闭,对于热压较大的车间其热损失不可 低估。大家经常可以看到无逆止装置的屋顶风机和轴流风机,在 热压作用下风机高速旋转,这一现象说明热压造成的风速相当 大,风筒内的风速可达2.0~3.0m/s以上。风机倒转对电动机 启动很不利,可能因启动电流过大而损坏。

注: 样本中第31页至40页的产品性能曲线不包含自垂百叶。

2. Impeller

Product Features

Backward aluminum alloy impeller with vaneless diffusion technology, effectively to improve the efficiency of the fan. Impeller hub uses the way of locking sleeve, to make the impeller fitted with the motor gapless, so it can endcapping minimize the assembly error caused by impeller hub fitting with motor shaft, to avoid the destruction of the balance, improve the balance level.

3. Motor

WPH series equip standard motor, its insulation class is F, ingress protection IP54, continuous operation temperature ranges from -20° C to 40° C, the other operation condition see the requirement.

4. Safty Net and Eliminator

WPH Series fans use high–grade stainless steel wire, C–type eliminator uses antirust corrosion–resistant aluminum, safe and reliable.

5. Gravity Shutter

High–grade aluminum alloy louvers mounted on the flashing, the size can be determined according to the size of the flashing. It can effectively prevent air reflux.

Many roof fans do not set off the device to prevent backflow, or after shutdown, the valve can not be reliably shut down, It is a thermal loss to be reckoned with. We often see the roof fan runs at high speed without backstop device, it turns out that thermal pressure can cause largish speed at $2.0 \sim 3.0$ m/s or more. It perhaps causes damage for motor because of excessive starting current caused by inversion.

Note: The product performance curves on pages 31 to 40 of the sample do not contain gravity shutter.

风机性能

1. 屋顶风机的选型计算

你选择屋顶风机时你得关注的四大要点:

a.风机型号的选择应该根据厂房实际情况,尽量选取与原窗口 尺寸相匹配的风机型号,实现良好的通风换气效果。排风侧尽量 不靠近附近建筑物,以防影响附近住户。如从室内带出的空气污 染环境,可以在风口安装喷水装置,让附近污染物集中回收,不 污染环境。

b.风机选型必备要素:风量、风压、功率、转速等。
c.风机风量是风速c与风道截面积s的乘积。所以风量计算也很简单,直接用公式q_v=cs便可算出风量。
d.车间所需风机数量计算:根据所选房间的换气次数来计算厂房所需总风量,进而计算得风机数量。
计算公式:N=V×n/q_v
其中:N--风机数量(台),
V--场地体积(m³),
n--换气次数(次/时).

2. 风机选型示意图例

型号	WPH710R
Туре	
风量	
Volume	qV=11000 m3/h
 **	
静压	
Static Pressure	Ps⊧=550 Pa
-+ F	
四川本	
Dynamic Pressure	PdF=24 Pa
図机转速	
Fan Speed	n=962 r/min
轴功率	
Shaft Power	Psh=2.93 KW
A声功率级	
A Sound Power Level	LwiA=87 dB(A)
靜 玉奴 平	
Static Efficiency	η s⊧ =60.3%

Performance Chart

1. Calculation of Selection

When you choose the roof fan you have to concern four main points:

a. Fan model selection should be based on actual plant conditions. try to select the fan model to match original window size, to achieve good ventilation effect. The outlet should not to close the buildings nearby, to prevent the impact of nearby residents, such as the air out of the indoor, you can install sprinklers in the outlet for absorbing pollutants. b. Fan selection essential elements: airflow, air pressure, power, speed and so on. c. Fan flow is the result that the velocity c multiply the duct cross-sectional areas. So the airflow calculation is very simple. directly use of the formula qu = cs. d. Calculate the number of fans: according to the room ventilation rate to calculate the workshop total air volume, and then calculated the number of fans. Calculation formula: N=V×n/g. Among: N-The number of the fans V- Field area(m³) n- Ventilation rate q_-Airflow(m³/h)

2. Example Of Cruve Reading





WPH SERIES WPH 系列风机产品说明 The WPH Series Roof Fan

说明

1)订货时须注明风机型号、转速、风量、风压、出风

口方向和旋转方

向。若需配套皮带、皮带轮、电机、安装底座等配件及 其它特殊要求

可在订货时提出。

2)在安装前应对风机各部件进行检查,对叶轮、主轴

和轴承等主要机

件应重点细致检查,如有损伤应修复后再安装使用。

 3)检查机壳和其它壳体内部,不应有掉入、遗留的工 具和杂物。

4)风机正式运转前,需检查电机的转向是否符合风机 转向的要求。

5)风管与出风口之间应采用软连接,接头不得拉紧。6)风机安装后用手或杠杆拨动叶轮,检查是否过紧或

碰撞现象,确认

无这些现象时方向可进行试转。

7)风机配用电机功率是指在特定工况下,风机内功率 加上机械损失

与电机容量安全系数而言,并非出风口全敞开时所需的 功率。为防止

电机超功率运行而烧毁,严禁风机出风口或进风口不接

管路或未加外

界任何阻力进行空运转。

8)风机在无较大腐蚀性气体、不含酸(碱)性和尘粒

物质<150mg/m

的气体、-20℃<温度 <85℃的气体环境下使用,风机

在运输装卸过程

中应小心轻放,防止碰撞挤压。

9)特殊环境使用,请与我司技术人员联系。

 When placing the order, it is necessary to state the type of fan, speed, air volume, air pressure, discharge direction, rotation direction, type of electric motor and its specifications.
 Prior to installation, the fan should be carefully inspected. Special care should be taken in checking the shalf, Wheel and

bearings. If there is an indication of any damage, the damaged

parts should be repaired or repaired before the fan is installed or commissioned.

 The inside of the scroll and casing need to be checked to make sure that there are no foreign objects inside the housing.

such as tools or loose parts.

Instructions

4) The rotational directions of the motor and Wheel should be checked to ensure that they are in comliance with the specification and purchase orders.

5) A flexible connector should be used between the fan out let

flange and its mating ductwork. The flex connector should not be over-stretched.

6) Following the installation, the Wheel should be turned by hand or with the use of a wrench to make sure that it turns freely without colliding with other parts of the fan. Once all this is done, the fan can be commissioned normally.

7) The rated motor power as calcutated herein might not be sufficient to drive the fan with an unrestricted discharge flow. Operating the fan with an unrestricted discharge outlet will result in flow rate that exceeds the specified fan capabilities. Such operation will quickly burn the motor and damage the fan.

Great care must be taken in operating the fan to make sure that

the maximum rated flows, as provided on the performance charts in this catalog, are not exceeded.8) The fan is limited for use in areas where air substances

are

non-corrosive, non-toxics and non-erosive and where dust particles are less than 150mg/m with a temperature between -20 and 85 . Special care should be taken during transportation, load and unload.

9) Special circumstances, please contact with our technical staff.

技术参数

Wheel diameter	叶轮直径	D = 361 mm	Fan weight	风机重量	m = 17 kg
Moment of inertia	转动惯量	J = 0.102kg m ²	Speed limit	极限转速	n _{max} =2750 r/min

性能曲线

Performance Curves

Technical Data

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口L_wA)。 Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_{wA} sound power levels for installation type A: free inlet, free outlet.



Measured in installation A according to AMCA Standard 210:







技术参数	Technical Data	技术参数	Technical Data	
Wheel diameter 叶轮直径 D = 406 mm	Fan weight 风机重量 m = 19 kg	Wheel diameter 叶轮直径 D = 456 mm	Fan weight 风机重量 m = 20 kg	
Moment of inertia $ table = 1 = 0.162 \text{ kg} \text{ m}^2 $	Speed limit 极限转速 n _{max} = 1780r/min	Moment of inertia 時动惯量	Speed limit 极限转速 n _{max} = 1705 r/min	

性能曲线

性能曲线

非使用区域 DO NOT USE IN THIS AREA

1000 -

500 ·

400

300

200

100-

30

20

10

.008 50

200 300

500

1000

0,1 0,2 0,5 1 2 5 10 20 50 100 200

2000 3000

5000

10000

006 40

静压

STATIC PRESSURE Ps (Pa)

STATIC EFFICIENCY η(%) 静压内效率

INNER POWER (KW 内功率

Performance Curves

- 40

BPE

≙

MPELLER

- 10

1780

1600

1400

1200

1000

900 A

700 ER ROT

600

500

400

÷

6 800

MPELL

VOLUME FLOW RATE

DYNAMIC PRESSURE 动压 Pd(Pa)

风量 Q(m³/h)

GAS DENSITY: 1.2kg/m³ 气体密度

63 57

39

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口L_wA)。

WPH400

46

++/++ 1

53 60 Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_wA sound power levels for installation type A: free inlet, free outlet.

Measured in installation A according to AMCA Standard 210:











Performance Curves

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口L_{wi}A)。

Performance certified is for installation type A: free inlet, free outlet.Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_wA sound power levels for installation type A: free inlet, free outlet.



Measured in installation A according to AMCA Standard 210:







技术参数	Technical Data	技术参数	Technical Data	
Wheel diameter 叶轮直径 D = 508 mm	Fan weight 风机重量 m = 23 kg	Wheel diameter 叶轮直径 D = 570 mm	Fan weight 风机重量 m = 28 kg	
Moment of inertia 转动惯量 J = 0.45 kg·m ²	Speed limit 极限转速 n _{max} = 1595 r/min	Moment of inertia 转动惯量 J = 0.74 kg·m ²	Speed limit 极限转速 n _{max} = 1545 r/min	

性能曲线

非使用区域 DO NOT USE IN THIS AREA

1000 -

500

400

300

200-

100-

50

40

30

20

B00 500

STATIC PRESSURE Ps (Pa)静压

STATIC EFFICIENCY η(%)静压内效率

INNER POW

内功率

0.1

1000

0.1 0.2 0.5 1 2 5 10 20

2000 3000

5000

10000

50 100 200

Performance Curves

GAS DENSITY: 1.2kg/m³ 气体密度

1595

1400

1200

1000

900

800 5

700

600

500

400

- 40

- 30

20

10

ROTATIONAL

MPELLER

VOLUME FLOW RATE

风量 Q(m³/h)

DYNAMIC PRESSURE 动压 Pd(Pa)

(s/u

J2(r

SPEED

IMPELLER TIP

63 57

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口L_wA)。

WPH500

46 53 60 Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_wA sound power levels for installation type A: free inlet, free outlet.

Measured in installation A according to AMCA Standard 210:









经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口L_wA)。

Performance Curves

Performance certified is for installation type A: free inlet, free outlet.Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_{wi}A sound power levels for installation type A: free inlet, free outlet.









技术参数	Technical Data	技术参数	Technical Data	
Wheel diameter 叶轮直径 D = 642 mm	Fan weight 风机重量 m = 36kg	Wheel diameter 叶彩直径 D =720 mm	Fan weight 风机重量 m = 43 kg	
Moment of inertia 转动惯量 J = 1.2 kg·m²	Speed limit 极限转速 n _{max} = 1545 r/min	Moment of inertia 转动惯量 J = 2.43 kg·m ²	Speed limit 极限转速 n _{max} = 1545 r/min	

性能曲线

非使用区域 DO NOT USE IN THIS AREA

1000

500

400

300

100-

50

40

30

20-

10

500

0.03

出 200 靈

SURE Ps (Pa)

E

STATIC F

STATIC EFFICIENCY η(%) 静压内效率

INNER POWER (KV

+++++++<u>+</u>50**\ **\

1000

内功率

Performance Curves

GAS DENSITY: 1.2kg/m³ 气体密度

1545

1400

1200

1000

900

800

700

600

500

350

300

260

20000 30000

(uju

2

ROTATIONAL

MPELLER

VOLUME FLOW RATE 风量 Q(m³/h)

DYNAMIC PRESSURE 动压 Pd(Pa)

50

40

30

20

10

公器速

SPEED U2(m/s)

MPELLER TIP

63

39

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口LwA)。

WPH630

5000

0.1 0.2 0.5 1 2 5 10 20 50 100 200

10000

2000 3000

Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_MA sound power levels for installation type A: free inlet, free outlet.

Measured in installation A according to AMCA Standard 210:







性能曲线

出口的声功率级(入口L_{wi}A)。

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不

International标准301计算。所示值为安装类型A:自由入口,自由

包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA

Performance Curves

Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_WA sound power levels for installation type A: free inlet, free outlet.



Measured in installation A according to AMCA Standard 210:







WPH800 FEG67 WPH 系列风机产品说明 The WPH Series Roof Fan

技术参数	Technical Data		技术参数	Technical Data	
Wheel diameter 叶轮直径 D = 813 mm	Fan weight 风机重量		Wheel diameter 叶轮直径 D = 914 mm	Fan weight 风机重量 m = 68 kg	
Moment of inertia $\frac{1}{1000}$ $J = 4.88$ kg·m ²	Speed limit 极限转速 n _{max} = 1078 r/min		Moment of inertia 转动惯量 J = 7.32 kg·m²	Speed limit 极限转速 n _{max} = 1078 r/min	

性能曲线

出口的声功率级(入口LwiA)。

性能曲线

非使用区域 DO NOT USE IN THIS AREA

1000 -

500

400

300

100

40

置 200

PRESSURE Ps (Pa)

STATIC F

STATIC EFFICIENCY n(%)静压内效率

INNER POWER (K

内市支

2000 3000

0.5 1

5000

5

10000

10 20

1000

0.1 0.2

0.8

Performance Curves

GAS DENSITY: 1.2kg/m³ 气体密度

1078

1000

900

·800 🎬

700

600

500

400

350

300 🗄

250

LEVEL UNA dBra

20000 30000

50 100 200

5000

0

ROTATION

APELL

VOLUME FLOW RATE 风量 Q(m³/h)

DYNAMIC PRESSURE

动压 Pd(Pa)

- 40

30 第3

U2(m/s)

ONAL SF

£

MPELLER

10

63 57

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口LwA)。

WPH800

46 53 60

Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_mA sound power levels for installation type A: free inlet, free outlet.

Measured in installation A according to AMCA Standard 210:







经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不

包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA

International标准301计算。所示值为安装类型A:自由入口,自由

Performance Curves

Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_WA sound power levels for installation type A: free inlet, free outlet.



Measured in installation A according to AMCA Standard 210:





	15.	$ \simeq $	Mr.L.	
107		太	丕V	
1×1		1	ᆇ	

Technical Data

Wheel diameter	叶轮直径	D = 1015 mm	Fan weight	风机重量	m =73 kg
Moment of inertia	转动惯量	J = 11.94 kg·m ²	Speed limit	极限转速	n _{max} = 1078 r/min

GAS DENSITY: 1.2kg/m³ 气体密度

1078

1000

900

800

700

· 600

500

400 ß

350

300

250

57

性能曲线

非使用区域 DO NOT USE IN THIS AREA

1000 -

500 -

400

300

200-静压

100-

50

40

30

20

1000

Ps (Pa) 🖁

STATIC

STATIC EFFICIENCY η (%) 静压内效率

0.1

2000 3000 5000

0.1 0.2 0.5 1 2

INNER POWER (KW 内功率

0.8

Performance Curves

- 60

50

40

30

轮爆速

U2(m/s) i

SPEED I 20

MPELLER TIP

EED n(r/min) 转速

TATIONAL

ER ROT

MPELLE 10

VOLUME FLOW RATE 风量 Q(m³/h)

DYNAMIC PRESSURE 动压 Pd(Pa)

经认证的性能是A类安装:自由入口,自由出口。各项性能额定值不 包括附属物(附件)的影响。所示A加权声音性能额定值已按AMCA International标准301计算。所示值为安装类型A:自由入口,自由 出口的声功率级(入口L_{wi}A)。

WPH1000

XH

OWER LEVEL Lv 率级 LwiA dB(A

20000 30000 50000

5 10 20 50 100 200

10000

Performance certified is for installation type A: free inlet, free outlet. Performance ratings do not include the effects of appurtenances (accessories). The A-weighted sound ratings shown have been calculated per AMCA International Standard 301. Values shown are for inlet L_MA sound power levels for installation type A: free inlet, free outlet.

Measured in installation A according to AMCA Standard 210:







WPH系列风机外形尺寸(mm)

单位:mm

WPH Series Fan Overall Dimension

尺寸 型号	А	В	W	D
WPH 355	361	237	102	231
WPH 400	406	266	115	260
WPH 450	456	299	129	292
WPH 500	508	332	143	325
WPH 560	570	373	161	364
WPH 630	642	420	181	410
WPH 710	720	474	203	461
WPH 800	813	535	230	520
WPH 900	914	600	259	585
WPH 1000	1015	667	287	650

040

WPH Concrete Roof Installation Diagram

WPH SERIES WPH 系列风机产品说明 The WPH Series Roof Fan



WPH系列风机外形尺寸(mm)

WPH Series Fan Overall Dimension



Airn 自攻螺钉 Self-tapping Screw 由安装方配置 Collocate by Installation Company 先将风机扣于泛水上,再用螺钉将风机固定, Buckle The Fan on Flashing First, Then Fix The Fan with Screws F 橡胶减震垫5-8mm Rubber Shockpad 5-8mm(Collocate by Instalaltion Company) 角钢Angle Steel 固定于泛水上 Fix on The Flashing 6 6 9 风阀(可选) Damper(is optional) 风管(安装方按需配置) 电源线导线管从室内接至风机 Install the Conduit Tube of Power Duct(Collocate by Instalaltion Company) Wire from Indoor to The Fan

> 混凝土屋面安装示意图 Concrete Roof Installation Diagram

WPH系列屋顶风机泛水尺寸表(mm)

WPH混泥土屋面安装示意图

WPH Installation Measurement Chart

型号 尺寸	F(泛水外沿)	H(泛水内沿)
WPH 355	645	485
WPH 400	695	535
WPH 450	695	535
WPH 500	750	590
WPH 560	852	692
WPH 630	890	730
WPH 710	933	773
WPH 800	1074	914
WPH 900	1284	1124
WPH 1000	1284	1124

单位:mm

尺寸 型号	С		М	N	V	D1	D2
WPH 355	329	336	132	170	718	513	696
WPH 400	371	379	149	192	809	578	785
WPH 450	417	425	167	215	910	650	882
WPH 500	463	473	186	239	1011	723	980
WPH 560	519	530	208	268	1133	809	1098
WPH 630	584	596	234	302	1274	910	1236
WPH 710	658	672	264	340	1436	1026	1392
WPH 800	742	757	298	384	1618	1156	1570
WPH 900	834	852	334	431	1820	1301	1765
WPH 1000	927	946	372	479	2023	1445	1961